

**Iowa Department of Natural Resources  
Title V Operating Permit**

**Name of Permitted Facility: Flint Hills Resources Menlo, LLC**

**Facility Location: 3363 Talon Avenue, Menlo, IA 50164**

**Air Quality Operating Permit Number: 15-TV-006R1**

**Expiration Date: March 22, 2025**

**Permit Renewal Application Deadline: September 22, 2024**

**EIQ Number: 92-6956**

**Facility File Number: 39-06-002**

---

**Responsible Official**

**Name: Jack Mitchell**

**Title: Plant Manager**

**Mailing Address: 3363 Talon Avenue, Menlo, IA 50164**

**Phone #: (515) 817-2922**

**Permit Contact Person for the Facility**

**Name: James Klar**

**Title: EHS Manager**

**Mailing Address: 3363 Talon Avenue, Menlo, IA 50164**

**Phone #: (641) 524-5660**

---

This permit is issued in accordance with 567 Iowa Administrative Code Chapter 22, and is issued subject to the terms and conditions contained in this permit.

**For the Director of the Department of Natural Resources**

---

Lori Hanson, Supervisor of Air Operating Permits Section

Date

# Table of Contents

<b>I. Facility Description and Equipment List</b> .....	<b>4</b>
<b>II. Plant - Wide Conditions</b> .....	<b>7</b>
<b>III. Emission Point Specific Conditions</b> .....	<b>11</b>
<b>IV. General Conditions</b> .....	<b>90</b>
G1. Duty to Comply	
G2. Permit Expiration	
G3. Certification Requirement for Title V Related Documents	
G4. Annual Compliance Certification	
G5. Semi-Annual Monitoring Report	
G6. Annual Fee	
G7. Inspection of Premises, Records, Equipment, Methods and Discharges	
G8. Duty to Provide Information	
G9. General Maintenance and Repair Duties	
G10. Recordkeeping Requirements for Compliance Monitoring	
G11. Evidence used in establishing that a violation has or is occurring.	
G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification	
G13. Hazardous Release	
G14. Excess Emissions and Excess Emissions Reporting Requirements	
G15. Permit Deviation Reporting Requirements	
G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations	
G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification	
G18. Duty to Modify a Title V Permit	
G19. Duty to Obtain Construction Permits	
G20. Asbestos	
G21. Open Burning	
G22. Acid Rain (Title IV) Emissions Allowances	
G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements	
G24. Permit Reopenings	
G25. Permit Shield	
G26. Severability	
G27. Property Rights	
G28. Transferability	
G29. Disclaimer	
G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification	
G31. Prevention of Air Pollution Emergency Episodes	
G32. Contacts List	
<b>V. Appendix A: Links to Standards</b> .....	<b>104</b>

## Abbreviations

acfm.....	actual cubic feet per minute
bu/hr.....	bushels per hour
CFR.....	Code of Federal Regulation
CE .....	control equipment
CEM.....	continuous emission monitor
DDGS.....	distillers dried grains with solubles
°F.....	degrees Fahrenheit
EIQ.....	emissions inventory questionnaire
EP.....	emission point
EU .....	emission unit
gr./dscf .....	grains per dry standard cubic foot
IAC.....	Iowa Administrative Code
DNR.....	Iowa Department of Natural Resources
kW.....	kilowatts
Mgals.....	million gallons
MVAC.....	motor vehicle air conditioner
NAICS.....	North American Industry Classification System
NSPS.....	new source performance standard
ppmv .....	parts per million by volume
lb./hr.....	pounds per hour
lb./MMBtu .....	pounds per million British thermal units
SCC.....	Source Classification Codes
scfm.....	standard cubic feet per minute
SIC .....	Standard Industrial Classification
tpy .....	tons per year
USEPA.....	United States Environmental Protection Agency

### Pollutants

PM.....	particulate matter
PM <sub>10</sub> .....	particulate matter ten microns or less in diameter
SO <sub>2</sub> .....	sulfur dioxide
NO <sub>x</sub> .....	nitrogen oxides
VOC.....	volatile organic compound
CO.....	carbon monoxide
HAP.....	hazardous air pollutant

# I. Facility Description and Equipment List

Facility Name: Flint Hills Resources Menlo, LLC

Permit Number: 15-TV-006R1

Facility Description: Industrial Organic Chemicals, NEC (SIC 2869)

## Equipment List

Emission Point Number	Emission Unit Number	Emission Unit Description	DNR Construction Permit Number
EP S20	EU P20	Grain Receiving/Handling	06-A-1180-S3
	EU P20A	Grain Bin A	
	EU P20B	Grain Bin B	
EP S25	EU P25	2 Steel Grain Bins	14-A-416
EP S30	EU P30	4 Hammermills	06-A-1181-S3
EP S10	EU 62	DDGS Dryer A	06-A-1183-S6
	EU 63	DDGS Dryer B	
	EU 64	DDGS Dryer C	
	EU 65	DDGS Dryer D	
	EU B10a	Heat Recovery Boiler A	
	EU B10b	Heat Recovery Boiler B	
	EU 19	Slurry Tank #1	
	EU 20	Slurry Tank #2	
	EU 21	Cook Tube #1	
	EU 22	Cook Tube #2	
	EU 23	Cook Flash Vessel	
	EU 24	Liquefaction Tank #1	
	EU 25	Liquefaction Tank #2	
	EU 33	Molecular Sieve Vaporizer	
	EU 34-EU 39	Molecular Sieve Bottles #1 - #6	
	EU 40	200 Proof Condenser	
	EU 41	200 Proof Flash Vessel	
	EU 42	200 Proof Flash Receiver	
	EU 43	CIP Screen/Tank	
	EU 44	Yeast Tank #1	
	EU 45	Yeast Tank #2	
	EU 46	Beer Column	
	EU 48	Side Stripper	
	EU 49	Rectifier Column	
EU 50	190 Proof Condenser		
EU 51	Reflux Tank		
EU 52	Regen Tank		
EU 53	Acid Wash Tank		

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
EP S10, (cont.)	EU 54	Centrate Tank #1	06-A-1183-S6 (cont.)
	EU 55	Centrate Tank #2	
	EU 56	Centrifuges	
	EU 57	Evaporators	
	EU 58	Methanator #1	
	EU 59	Methanator #2	
	EU 60	Methanator #3	
	EU 61	Methanator #4	
EP S40	EU 26	Fermenter #1	06-A-1185-S6
	EU 27	Fermenter #2	
	EU 28	Fermenter #3	
	EU 29	Fermenter #4	
	EU 30	Fermenter #5	
	EU 31	Fermenter #6	
	EU 32	Fermenter #7	
	EU 66	Fermenter #8	
	EU 67	Fermenter #9	
EU 47	Beer Well		
EP S70	EU P70	DDGS Cooler	07-A-295-S3
EP S90	EU P90	DDGS Loadout Truck	06-A-1182-S3
	EU P90(2)	DDGS Loadout Rail	
EP SEP22	EU F50	Product Loadout & Vapor Recovery	06-A-1190-S4
EP 11	EU 58	Biomethanator #1	07-A-296-S2
	EU 59	Biomethanator #2	
	EU 60	Biomethanator #3	
	EU 61	Biomethanator #4	
EP S80	EU P80	Cooling Tower	06-A-1192-S3
EP T61	EU T61	Denatured Ethanol Storage Tank	06-A-1195-S3
EP T62	EU T62	Denatured Ethanol Storage Tank	06-A-1196-S3
EP T63	EU T63	200 Proof Ethanol Storage Tank	07-A-297-S1
EP T65	EU T65	190 Proof Ethanol Storage Tank	06-A-1194-S2
EP T64	EU T64	Denaturant Storage Tank	06-A-1197-S3
EP FP	EU FP	Fire Water Pump	06-A-1191-S3
EP F110	EU F110	Equipment Leaks	06-A-1193-S3
EP F120	EU F120	Truck Traffic on Plant Roads	06-A-1198-S3
EP F130	EU F130	WDGS Storage and Loadout	07-A-298-S1
EP S150	EU P150	Whole Stillage Tank	14-A-417
EP S160	EU P160	Thin Stillage Tank	14-A-418
EP F22	EU F22	Open Transportation Devices	14-A-419
EP S33	EU 71	Grain Receiving #2	18-A-074
	EU 72	Grain Elevator #3	
	EU 73	Grain Bin #3	

---

**Insignificant Activities Equipment List**

---

<b>Insignificant Emission Unit Number</b>	<b>Insignificant Emission Unit Description</b>
EU TS-8411	Corrosion Inhibitor Tank (2,300 gal)
EU TF-6810	Syrup Storage Tank (180,000 gal)
EU TF-2112	Methanator Feed Tank (374,000 gal)
EU TF-2101	Cook Water Tank (374,000 gal)
EU TP-12501	Sulfuric Acid Tank (8,000 gal)
S200	Diesel Tank (1,000 gal)
S201	Corn Oil Loadout
S202	Corn Oil Vents
S203	Portable Diesel Tank (100 gal)
S204	Ground Corn Pile
S205	Fire Pump Diesel Tank (360 gal)
EU TK-13800	Corn Oil Tank 1 (20,000 gal)
EU TK-13801	Corn Oil Tank 2 (20,000 gal)
EU TK-13802	Corn Oil Tank 3 (20,000 gal)
EU TK-13803	Corn Oil Tank 4 (20,000 gal)

## II. Plant-Wide Conditions

Facility Name: Flint Hills Resources Menlo, LLC  
Permit Number: 15-TV-006R1

Permit conditions are established in accordance with 567 Iowa Administrative Code rule 22.108

---

### Permit Duration

The term of this permit is: 5 years  
Commencing on: March 23, 2020  
Ending on: March 22, 2025

Amendments, modifications and reopenings of the permit shall be obtained in accordance with 567 Iowa Administrative Code rules 22.110 - 22.114. Permits may be suspended, terminated, or revoked as specified in 567 Iowa Administrative Code Rules 22.115.

---

### Emission Limits

*Unless specified otherwise in the Source Specific Conditions, the following limitations and supporting regulations apply to all emission points at this plant:*

Opacity (visible emissions): 40% opacity  
Authority for Requirement: 567 IAC 23.3(2)"d"

Sulfur Dioxide (SO<sub>2</sub>): 500 parts per million by volume  
Authority for Requirement: 567 IAC 23.3(3)"e"

#### Particulate Matter:

No person shall cause or allow the emission of particulate matter from any source in excess of the emission standards specified in this chapter, except as provided in 567 – Chapter 24. For sources constructed, modified or reconstructed on or after July 21, 1999, the emission of particulate matter from any process shall not exceed an emission standard of 0.1 grain per dry standard cubic foot of exhaust gas, except as provided in 567 – 21.2(455B), 23.1(455B), 23.4(455B) and 567 – Chapter 24.

For sources constructed, modified or reconstructed prior to July 21, 1999, the emission of particulate matter from any process shall not exceed the amount determined from Table I, or amount specified in a permit if based on an emission standard of 0.1 grain per standard cubic foot of exhaust gas or established from standards provided in 23.1(455B) and 23.4(455B).  
Authority for Requirement: 567 IAC 23.3(2)"a"

Fugitive Dust: Attainment and Unclassified Areas - A person shall take reasonable precautions to prevent particulate matter from becoming airborne in quantities sufficient to cause a nuisance as defined in Iowa Code section 657.1 when the person allows, causes or permits any materials to be handled, transported or stored or a building, its appurtenances or a construction haul road to be

used, constructed, altered, repaired or demolished, with the exception of farming operations or dust generated by ordinary travel on unpaved roads. Ordinary travel includes routine traffic and road maintenance activities such as scarifying, compacting, transporting road maintenance surfacing material, and scraping of the unpaved public road surface. (the preceding sentence is State Only) All persons, with the above exceptions, shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond the lot line of the property on which the emissions originate. The public highway authority shall be responsible for taking corrective action in those cases where said authority has received complaints of or has actual knowledge of dust conditions which require abatement pursuant to this subrule. Reasonable precautions may include, but not be limited to, the following procedures.

1. Use, where practical, of water or chemicals for control of dusts in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land.
2. Application of suitable materials, such as but not limited to asphalt, oil, water or chemicals on unpaved roads, material stockpiles, race tracks and other surfaces which can give rise to airborne dusts.
3. Installation and use of containment or control equipment, to enclose or otherwise limit the emissions resulting from the handling and transfer of dusty materials, such as but not limited to grain, fertilizer or limestone.
4. Covering, at all times when in motion, open-bodied vehicles transporting materials likely to give rise to airborne dusts.
5. Prompt removal of earth or other material from paved streets or to which earth or other material has been transported by trucking or earth-moving equipment, erosion by water or other means.
6. Reducing the speed of vehicles traveling over on-property surfaces as necessary to minimize the generation of airborne dusts.

Authority for Requirement: 567 IAC 23.3(2)"c"

**40 CFR 60 Subpart A Requirements**

This facility is an affected source and these *General Provisions* apply to the facility. The affected units are Thermal Oxidizer 1, Thermal Oxidizer 2, EU T61, EU T62, EU T63, EU T64, EU T65, EU F110, EU 71, EU 73, EU 74 and EP FP.

See Appendix A for a link to the Standard.

Authority for 40 CFR 60 Subpart A

Requirements:

567 IAC 23.1(2)

**40 CFR 60 Subpart Db Requirements**

This facility is subject to Standards of Performance for *Industrial Commercial Institutional Steam Generating Units*. The affected units are Thermal Oxidizer 1 and Thermal Oxidizer 2.

See Appendix A for a link to the Standard.

Authority for 40 CFR 60 Subpart Db

Requirements:

567 IAC 23.1(2) "ccc"

**40 CFR 60 Subpart DD Requirements**

This facility is subject to Standards of Performance for Grain Elevators. The affected units are EU 71, EU 72 and EU 73.

See Appendix A for a link to the Standard.

Authority for                                   40 CFR 60 Subpart DD  
Requirements:  
  567 IAC 23.1(2) "ooo"

**40 CFR 60 Subpart Kb Requirements**

This facility is subject to Standards of Performance for *Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels)* for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984. The affected units are EU T61, EU T62, EU T63, EU T64, and EU T65.

See Appendix A for a link to the Standard.

Authority for                                   40 CFR 60 Subpart Kb  
Requirements:  
  567 IAC 23.1(2) "ddd"

**40 CFR 60 Subpart VVa Requirements**

This facility is subject to Standards of Performance for *Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry* for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006. The affected units are equipment in VOC service and any applicable devices and systems (as defined in 40 CFR 60.481a) in the entire facility. The owner or operator shall comply with the applicable requirements in 40 CFR 60.480a through 60.489a, including recordkeeping requirements in 40 CFR 60.486a and reporting requirements in 40 CFR 60.487a.

See Appendix A for a link to the Standard.

Authority for                                   40 CFR 60 Subpart VVa  
Requirements:  
  567 IAC 23.1(2) "nn"

**40 CFR 60 Subpart IIII Requirements**

This facility is subject to Standards of Performance for *Stationary Compression Ignition Internal Combustion Engines*. The affected unit is EU FP. Applicable requirements are incorporated in the Emission Point-Specific conditions.

See Appendix A for a link to the Standard.

Authority for                                   40 CFR 60 Subpart IIII  
Requirements:  
  567 IAC 23.1(2) "yyy"

#### **40 CFR 63 Subpart A Requirements**

This facility is subject to National Emission Standards for Hazardous Air Pollutants for *General Provisions*. The affected units are EP S10, EP S40, EP SEP22, EP T64, EP F110 and EP FP. See Appendix A for a link to the Standard.

Authority for                                 40 CFR 63 Subpart A  
Requirements:                                 567 IAC 23.1(4)

#### **40 CFR 63 Subpart FFFF Requirements**

This facility is subject to National Emission Standards for Hazardous Air Pollutants for *Miscellaneous Organic Chemical Manufacturing*. The affected units are EP S10, EP S40, EP SEP22, EP T64 and EP F110.

See Appendix A for a link to the Standard.

Authority for                                 40 CFR 63 Subpart FFFF  
Requirements:                                 567 IAC 23.1(4) "cf"

#### **40 CFR 63 Subpart ZZZZ Requirements**

This facility is subject to National Emission Standards for Hazardous Air Pollutants for *Stationary Reciprocating Internal Combustion Engines (RICE NESHAP)*. The affected unit is EU FP. Applicable requirements are incorporated in the Emission Point-Specific conditions. See Appendix A for a link to the Standard.

Authority for                                 40 CFR 63 Subpart ZZZZ  
Requirements:                                 567 IAC 23.1(4) "cz"

### III. Emission Point-Specific Conditions

Facility Name: Flint Hills Resources Menlo, LLC  
Permit Number: 15-TV-006R1

---

#### **Emission Point ID Number: EP S20**

#### Associated Equipment

**Table: Grain Receiving and Storage**

<b>Emission Unit</b>	<b>Emissions Unit Description</b>	<b>Raw Material/Fuel</b>	<b>Rated Capacity</b>	<b>Control Equipment</b>
EU P20	Grain Receiving/Handling System	Grain	40,000 bu/hr	Baghouse (C20)
EU P20a	Grain Bin A	Grain	500,000 bu	
EU P20b	Grain Bin B	Grain	500,000 bu	

#### **Applicable Requirements**

##### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1180-S3  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of "no visible emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 1.67 lb/hr; 0.1 gr/dscf

Authority for Requirement: DNR Construction Permit 06-A-1180-S3  
567 IAC 23.4(7)

##### **Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. The owner or operator shall maintain the Baghouse (CE C20) according to the facility's (Facility ID: 39-06-002) operation and maintenance plan. The owner or operator shall maintain a log of all maintenance and inspection activities performed on the Baghouse (CE

- C20). This log shall include, but is not necessarily limited to:
  - a. The date any inspection and/or maintenance was performed on the Baghouse (CE C20);
  - b. Any issues identified during the inspection and the date each issue was resolved;
  - c. Any issues addressed during the maintenance activities and the date each issue was resolved; and
  - d. Identification of the staff member performing the maintenance or inspection.
- B. The grain bins shall be maintained at negative pressure at all times that the bins are in operation.

Authority for Requirement: DNR Construction Permit 06-A-1180-S3

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 162

Stack Opening (inches, dia.): 38

Exhaust Flow Rate (scfm): 27,000

Exhaust Temperature (°F): Ambient

Discharge Style: Vertical Unobstructed

Authority for Requirement: DNR Construction Permit 06-A-1180-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

# Compliance Assurance Monitoring Plan for Flint Hills Resources Menlo, LLC Facility located in Menlo, Iowa

## EP S20 –Grain Receiving, Storage, and Handling System Baghouse

### I. Background

#### A. Emissions Unit

Description: Grain Receiving/Handling, Grain Bin A and B (EU P20, 20a, 20b)

Facility: Flint Hills Resources Menlo, LLC  
Menlo, Iowa

#### B. Applicable Regulation, Emission Limit, and Monitoring Requirements

Regulation No.: Construction Permit 06-A-1180-S3

PM Emission Limit or Standard: 1.67 lb/hr; 0.1 gr/dscf

PM<sub>10</sub> Emission Limit or Standard: N/A

PM<sub>2.5</sub> Emission Limit or Standard: N/A

#### C. Control Technology

Fabric Filter Baghouse (CE C20)

### II. Grain Receiving, Storage, and Handling System Baghouse Monitoring Approach

#### A. Indicator

Pressure drop will be used as the performance indicator.

#### B. Measurement Approach

The key elements of the monitoring approach, including the indicators to be monitored, indicator ranges, and performance criteria are presented in Table 1.

**Table 1: Monitoring Approach**

<b>I. Indicator</b>	
Indicator	Differential pressure across the baghouse
Measurement / Approach	The pressure drop will be monitored and recorded at least once each day of operation.
<b>II. Indicator Range</b>	
Range	A pressure drop of 0 to 6 inches of water shall be maintained during operation.
Corrective Action	Procedures, system parameters, data trends will be reviewed and the functional operation of the equipment will be assessed to determine the cause of the excursion. Once the cause is identified, a repair or adjustment will be implemented to procedures to address the excursion.
QIP Threshold	An accumulation of excursions outside the indicator range of six or more for a reporting period excluding periods of startup, shutdown and malfunction.
<b>III. Performance Criteria</b>	
Data Representativeness	Pressure drop is measured across the system
Verification of Operational Status	Records of pressure drop readings will be maintained for five years.
QA/QC Practices and Criteria	Calibrate, maintain, and operate instrumentation in accordance with the Facility Operation and Maintenance Plan.
Monitoring Frequency	The pressure drop will be recorded a minimum of once per day during operations.
Data Collection Procedures	The pressure drop will be recorded electronically or manually.
Averaging period	Not applicable.
Record Keeping	Maintain for a period of five years records and corrective actions taken in response to excursions.
Reporting	Number, duration, and cause of any excursion and the corrective action taken.
Frequency	Semiannually.

**III. Justification**

A. Background

PM, PM<sub>10</sub>, and PM<sub>2.5</sub> emissions from the Grain Receiving, Storage, and Handling System (EU P20, 20a, 20b) are controlled by the Grain Receiving, Storage, and Handling Baghouse.

B. Rationale for Selection of Performance Indicator

Baghouses operate by collecting particulate on porous fabric bags, thus resulting in a pressure differential across the system. The gas stream is passed through the fabric which results in pressure; too much pressure indicates a possible plugging of the system and too little indicates possible

bag breakage. Therefore, pressure drop is the best indicator of baghouse performance.

C. Rationale for Selection of Indicator Level

Baghouses remove dust from a gas stream by passing the stream through a porous fabric. Particles form a porous cake on the fabric that acts as the filtration device. This porous cake is routinely removed and collected and returned to the process. Baghouses are highly efficient for controlling filterable PM, PM<sub>10</sub>, and PM<sub>2.5</sub>. Baghouses are subject to failure if they are not properly operated and maintained. An indicator pressure drop of 0 to 6 inches of water is recommended to achieve the required control efficiency.

The selected QIP threshold for the daily pressure drop is six excursions during a semi-annual reporting period. If the QIP threshold is exceeded during a semi-annual reporting period, a QIP will be developed and implemented.

## **Emission Point ID Number: EP S25**

### Associated Equipment

Associated Emission Unit ID Numbers: EU P25  
Emissions Control Equipment ID Number: CE C25  
Emissions Control Equipment Description: Baghouse

---

Emission Unit vented through this Emission Point: EU P25  
Emission Unit Description: 2 Steel Grain Bins  
Raw Material/Fuel: Grain  
Rated Capacity: 510,000 bushels (each bin)

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 14-A-416  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of "no visible emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf

Authority for Requirement: DNR Construction Permit 14-A-416  
567 IAC 23.4(7)

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

#### **Operating Limits**

- A. The control equipment shall be inspected and maintained according to manufacturer's recommendations.
- B. The grain throughput through the two steel grain bins shall not exceed 378,000 tons of grain per twelve (12) month period, rolled monthly.

**Reporting & Record keeping**

- A. The owner or operator shall keep records of control equipment inspections and maintenance.
- B. At the end of each month, record the amount of grain (in tons) that was put into the two steel grain bins over the previous month.
- C. At the end of each month, record the amount of grain (in tons) that was put into the two steel grain bins over the previous twelve (12) months.

Authority for Requirement: DNR Construction Permit 14-A-416

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 160

Stack Opening (inches, dia.): 20

Exhaust Flow Rate (scfm): 6,000

Exhaust Temperature (°F): Ambient

Discharge Style: Vertical Unobstructed

Authority for Requirement: DNR Construction Permit 14-A-416

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**                      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**                      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**                      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

**Compliance Assurance Monitoring Plan for Flint Hills Resources Menlo, LLC  
Facility located in Menlo, Iowa**

**EP S25 – Grain Storage Bins Baghouse**

**I. Background**

A. Emissions Unit

Description: Grain Storage Bins (EU P25)

Facility: Flint Hills Resources Menlo, LLC  
Menlo, Iowa

B. Applicable Regulation, Emission Limit, and Monitoring Requirements

Regulation No.: Construction Permit 14-A-416

PM Emission Limit or Standard: 0.1 gr/dscf

C. Control Technology

Fabric Filter Baghouse (CE C25)

**II. DDGS Cooler Baghouse Monitoring Approach**

A. Indicator

Pressure drop will be used as the performance indicator.

B. Measurement Approach

The key elements of the monitoring approach, including the indicators to be monitored, indicator ranges, and performance criteria are presented in Table 1.

**Table 2: Monitoring Approach**

<b>I. Indicator</b>	
Indicator	Differential pressure across the baghouse
Measurement / Approach	The pressure drop will be monitored and recorded at least once each day of operation.
<b>II. Indicator Range</b>	
Range	A pressure drop of 0 to 6 inches of water shall be maintained during operation.
Corrective Action	Procedures, system parameters, data trends will be reviewed and the functional operation of the equipment will be assessed to determine the cause of the excursion. Once the cause is identified, a repair or adjustment will be implemented to procedures to address the excursion.
QIP Threshold	An accumulation of excursions outside the indicator range of six or more for a reporting period excluding periods of startup, shutdown and malfunction.
<b>III. Performance Criteria</b>	
Data Representativeness	Pressure drop is measured across the system
Verification of Operational Status	Records of pressure drop readings will be maintained for five years.
QA/QC Practices and Criteria	Calibrate, maintain, and operate instrumentation in accordance with Facility Operation and Maintenance Plan.
Monitoring Frequency	The pressure drop will be recorded a minimum of once per day during operations.
Data Collection Procedures	The pressure drop will be recorded electronically or manually.
Averaging period	Not applicable.
Record Keeping	Maintain for a period of five years records and corrective actions taken in response to excursions.
Reporting	Number, duration, and cause of any excursion and the corrective action taken.
Frequency	Semiannually.

**III. Justification**

A. Background

PM emissions from the Grain Bins (EU P25) are controlled by the Grain Bin Baghouse.

B. Rationale for Selection of Performance Indicator

Baghouses operate by collecting particulate on porous fabric bags, thus resulting in a pressure differential across the system. The gas stream is passed through the fabric which results in pressure; too much pressure indicates a possible plugging of the system and too little indicates possible bag breakage. Therefore, pressure drop is the best indicator of baghouse performance.

C. Rationale for Selection of Indicator Level

Baghouses remove dust from a gas stream by passing the stream through a porous fabric. Particles form a porous cake on the fabric that acts as the filtration device. This porous cake is routinely removed and collected and returned to the process. Baghouses are highly efficient for controlling filterable PM. Baghouses are subject to failure if they are not properly operated and maintained. An indicator pressure drop of 0 to 6 inches of water is recommended to achieve the required control efficiency.

The selected QIP threshold for the daily pressure drop is six excursions during a semi-annual reporting period. If the QIP threshold is exceeded during a semi-annual reporting period, a QIP will be developed and implemented.

## **Emission Point ID Number: EP S30**

### Associated Equipment

Associated Emission Unit ID Numbers: EU P30  
Emissions Control Equipment ID Number: CE C30  
Emissions Control Equipment Description: Baghouse

---

Emission Unit vented through this Emission Point: EU P30  
Emission Unit Description: 4 Hammermills  
Raw Material/Fuel: Grain  
Rated Capacity: 1,500 bu/hr (each)

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1181-S3  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of "no visible emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 1.20 lb/hr; 0.1 gr/dscf

Authority for Requirement: DNR Construction Permit 06-A-1181-S3  
567 IAC 23.4(7)

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. The owner or operator shall maintain the Baghouse (CE C30) according to the facility's (Facility ID: 39-06-002) operation and maintenance plan. The owner or operator shall maintain a log of all maintenance and inspection activities performed on the Baghouse (CE C30). This log shall include, but is not necessarily limited to:
  - a. The date any inspection and/or maintenance was performed on the Baghouse (CE C30);
  - b. Any issues identified during the inspection and the date each issue was resolved;
  - c. Any issues addressed during the maintenance activities and the date each issue

- was resolved; and  
d. Identification of the staff member performing the maintenance or inspection.

Authority for Requirement: DNR Construction Permit 06-A-1181-S3

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 162

Stack Opening (inches, dia.): 38

Exhaust Flow Rate (scfm): 18,400

Exhaust Temperature (°F): Ambient

Discharge Style: Vertical Unobstructed

Authority for Requirement: DNR Construction Permit 06-A-1181-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**            Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**        Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**                Yes  No

Authority for Requirement: 567 IAC 22.108(3)

**Compliance Assurance Monitoring Plan for Flint Hills Resources Menlo, LLC  
Facility located in Menlo, Iowa**

**EP S30 – Hammermill Baghouse**

**I. Background**

A. Emissions Unit

Description: Hammermills (EU P30)  
Facility: Flint Hills Resources Menlo, LLC  
Menlo, Iowa

B. Applicable Regulation, Emission Limit, and Monitoring Requirements

Regulation No.: Construction Permit 06-A-1181-S3  
PM Emission Limit or Standard: 1.20 lb/hr; 0.1 gr/dscf  
PM<sub>10</sub> Emission Limit or Standard: N/A  
PM<sub>2.5</sub> Emission Limit or Standard: N/A

C. Control Technology

Baghouse (CE C30)

**II. Hammermill Baghouse Monitoring Approach**

A. Indicator

Pressure drop will be used as the performance indicator.

B. Measurement Approach

The key elements of the monitoring approach, including the indicators to be monitored, indicator ranges, and performance criteria are presented in Table 1.

**Table 3: Monitoring Approach**

<b>I. Indicator</b>	
Indicator	Differential pressure across the baghouse
Measurement / Approach	The pressure drop will be monitored and recorded at least once each day of operation.
<b>II. Indicator Range</b>	
Range	A pressure drop of 0 to 6 inches of water shall be maintained during operation.
Corrective Action	Procedures, system parameters, data trends will be reviewed and the functional operation of the equipment will be assessed to determine the cause of the excursion. Once the cause is identified, a repair or adjustment will be implemented to procedures to address the excursion.
QIP Threshold	An accumulation of excursions outside the indicator range of six or more for a reporting period excluding periods of startup, shutdown and malfunction.
<b>III. Performance Criteria</b>	
Data Representativeness	Pressure drop is measured across the system
Verification of Operational Status	Records of pressure drop readings will be maintained for five years.
QA/QC Practices and Criteria	Calibrate, maintain, and operate instrumentation in accordance with the Facility Operation and Maintenance Plan.
Monitoring Frequency	The pressure drop will be recorded a minimum of once per day during operations.
Data Collection Procedures	The pressure drop will be recorded electronically or manually.
Averaging period	Not applicable.
Record Keeping	Maintain for a period of five years records and corrective actions taken in response to excursions.
Reporting	Number, duration, and cause of any excursion and the corrective action taken.
Frequency	Semiannually.

### **III. Justification**

#### **A. Background**

PM, PM<sub>10</sub>, and PM<sub>2.5</sub> emissions from the Hammermills (EU S30) are controlled by the Hammermill Baghouse.

#### **B. Rationale for Selection of Performance Indicator**

Baghouses operate by collecting particulate on porous fabric bags, thus resulting in a pressure differential across the system. The gas stream is passed through the fabric which results in pressure; too much pressure indicates a possible plugging of the system and too little indicates possible bag breakage. Therefore, pressure drop is the best indicator of baghouse performance.

C. Rationale for Selection of Indicator Level

Baghouses remove dust from a gas stream by passing the stream through a porous fabric. Particles form a porous cake on the fabric that acts as the filtration device. This porous cake is routinely removed and collected and returned to the process. Baghouses are highly efficient for controlling filterable PM, PM<sub>10</sub>, and PM<sub>2.5</sub>. Baghouses are subject to failure if they are not properly operated and maintained. An indicator pressure drop of 0 to 6 inches of water is recommended to achieve the required control efficiency.

The selected QIP threshold for the daily pressure drop is six excursions during a semi-annual reporting period. If the QIP threshold is exceeded during a semi-annual reporting period, a QIP will be developed and implemented.





<sup>(3)</sup>The annual emission limit only applies to the fossil fuel fired boilers (CE 10a/EU B10a and CE 10b/EU B10b).

Pollutant: Volatile Organic Compounds (VOC)  
 Emission Limit: 4.6 lb/hr  
 Authority for Requirement: DNR Construction Permit 06-A-1183-S6

Pollutant: Carbon Monoxide (CO)  
 Emission Limit: 20.71 lb/hr <sup>(4)</sup>  
 Authority for Requirement: DNR Construction Permit 06-A-1183-S6  
<sup>(4)</sup>Emission limit is based on a 30-day rolling average basis.

Pollutant: Total HAP  
 Emission Limit: 20 ppmv <sup>(5)</sup>  
 Authority for Requirement: DNR Construction Permit 06-A-1183-S6  
 40 CFR 63 Subpart FFFF  
 567 IAC 23.1(4)"cf"

<sup>(5)</sup>The actual limit from the MON MACT (40 CFR Subpart FFFF) is 98% or more reduction of total organic HAP or no more than 20 ppm<sub>v</sub> total organic HAP in the exhaust stream.

**NSPS and NESHAP Applicability**

EU ID	Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
CE C10a and CE C10b	A	General Provisions	NA	23.1(2)	§60.1 – §60.19
	Db	Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units	Greater than 100 MMBtu/hr Heat Input	23.1(2)"ccc"	§60.40b – §60.49b

Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
A	General Provisions	NA	23.1(4)	§63.1 – §63.15
FFFF	National Emission Standards for Hazardous Air Pollutants: Miscellaneous Organic Chemical Manufacturing	NA	23.4(4)"cf"	§63.4230 – §63.2550

**Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. The control equipment shall be operated and maintained according to the facility’s (Facility ID: 39-06-002) operation and maintenance plan. The owner or operator shall

maintain a log of all maintenance and inspection activities performed on the control equipment. This log shall include, but is not necessarily limited to:

- a. The date any inspection and/or maintenance was performed on the control equipment;
  - b. Any issues identified during the inspection and the date each issue was resolved;
  - c. Any issues addressed during the maintenance activities and the date each issue was resolved; and
  - d. Identification of the staff member performing the maintenance or inspection.
- B. The thermal oxidizers shall be operated at all times the dryers or distillation equipment is being used. Each thermal oxidizer shall maintain a temperature (daily average) during operation at or above the average temperature of the oxidizer recorded during the most recent performance test which demonstrated compliance with the emission limits. The owner or operator shall keep hourly records of the operating temperature of each thermal oxidizer. The owner or operator shall keep records of the frequency and amount of time the thermal oxidizer malfunctions, and estimate the emissions emitted during said malfunctions.
- C. The dryers or thermal oxidizers shall combust only natural gas and/or process off gases. The owner or operator shall record and maintain records of the amounts of each fuel combusted during each day, and calculate the annual capacity factor on a 12 month rolling average basis with a new annual capacity factor calculated at the end of each calendar month for the previous month, as required in 40 CFR §60.49b(d) for the thermal oxidizer/waste heat boiler. The annual capacity factor is defined as the ratio between the actual heat input to a steam generating unit during a calendar year, and the potential heat input had it been operated for 8,760 hours during a calendar year at the maximum steady state design heat input capacity.
- D. The owner or operator shall follow all applicable requirements from Subpart Db, 40 CFR §60.40b through §60.49b. The owner or operator shall maintain records of the following information for each steam generating unit operating day, as required in 40 CFR §60.49b(g). This information shall also be submitted in a report, as required in 40 CFR §60.49b(i). This information shall include the following:
- a. Calendar date;
  - b. Average hourly nitrogen oxides emission (as NO<sub>2</sub>) rates measured;
  - c. 30-day average nitrogen oxides emission rates calculated at the end of each steam generating unit operating day from the measured hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days;
  - d. Identification of the steam generating unit operating days when the calculated 30-day average nitrogen oxides emission rates are in excess of the emission standard, with the reason for such excess emissions as well as a description of corrective actions taken;
  - e. Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken;
  - f. Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data;
  - g. Identification of "F" factor used for calculations, method of determination, and type of fuel combusted;

- h. Identification of the times when the pollutant concentrations exceeded the full span of the continuous monitoring system;
  - i. Description of any modifications to the continuous monitoring system that could affect the ability of the CEMS to comply with Performance Specification 2 or 3; and
  - j. Results of daily CEMS drift tests and quarterly accuracy assessments as required under 40 CFR Appendix F, Procedure 1.
- E. As required by 40 CFR §63.2450(e)(1), the owner or operator of this equipment shall comply with the requirements of 40 CFR §63.982(c). This also requires the owner or operator to comply with the requirements of 40 CFR §63.988 and any other applicable referenced requirement.
- F. As required by 40 CFR §63.6(e), the facility shall develop and implement a written startup, shutdown and malfunction plan (SSMP) unless otherwise exclude within the applicable standards.
- G. The owner or operator shall use the NO<sub>x</sub> CEM data, the natural gas fuel usage records, and the equation below to calculate and record the monthly NO<sub>x</sub> emissions from the TO/HRSGs. The owner or operator shall maintain records of all data used to perform the calculations:

$$a. \text{NO}_x \left( \frac{\text{ton}}{\text{month}} \right) = [S10_{\text{NO}_x}] \times \left[ \frac{1.2 \times \text{NG}_{\text{TO/HRSG}}}{(1.2 \times \text{NG}_{\text{TO/HRSG}}) + (\text{NG}_{\text{Dryers}})} \right]$$

Where: NO<sub>x</sub> (ton/month) = NO<sub>x</sub> from TO/HRSGs  
 S10<sub>NO<sub>x</sub></sub> = total NO<sub>x</sub> emissions from stack S10 as measured by the CEM, in tons  
 NG<sub>TO/HRSG</sub> = amount of natural gas combusted in the TO/HRSGs in MMBtu  
 NG<sub>Dryers</sub> = amount of natural gas combusted in the Dryers in MMBtu  
 1.2 = compliance margin

- H. The owner or operator shall use the equation in Condition G to determine the 12-month rolling total emissions of NO<sub>x</sub> from the TO/HRSGs for each calendar month. New 12-month totals shall be calculated at the end of each month for the previous month. As an alternative to the equation in G, the owner or operator may assume that all NO<sub>x</sub> emissions from stack S10 are from the TO/HRSGs.
- I. The owner or operator shall monitor the natural gas input to the dryers and the TO/HRSGs separately. The owner or operator shall record the amount of natural gas input to the dryers and the TO/HRSGs in MMBtu/month.

Authority for Requirement: DNR Construction Permit 06-A-1183-S6

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

- Stack Height (ft, from the ground): 125
- Stack Opening (inches, dia.): 120
- Exhaust Flow Rate (scfm): 153,400
- Exhaust Temperature (°F): 300
- Discharge Style: Vertical Unobstructed
- Authority for Requirement: DNR Construction Permit 06-A-1183-S6

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Compliance Demonstration Table**

<b>Pollutant</b>	<b>Compliance Methodology</b>	<b>Frequency</b>	<b>Test Run Time</b>	<b>Test Method</b>
VOC	Stack Test	See Footnote 1	1 hour	40 CFR 63, Appendix A, Method 320 or 40 CFR 60, Appendix A, Method 18
HAP	Stack Test	See Footnote 1	1 hour	40 CFR 63, Appendix A, Method 320 or 40 CFR 60, Appendix A, Method 18

<sup>(1)</sup> Testing for VOC and Total Organic HAP shall both be conducted each time testing is required to be completed. Testing shall be completed according to the schedule required by NESHAP Subpart FFFF (40 CFR 63 §63.2430 - §63.2550) or at a minimum of once every 3 years.

Authority for Requirement: DNR Construction Permit 06-A-1183-S6

**Continuous Emissions Monitoring:**

The owner or operator shall install, calibrate, maintain and operate a continuous monitoring system, and record the output of the system, for measuring **nitrogen oxide (NO<sub>x</sub>)** emissions discharged to the atmosphere. The CEM shall be operated and data collected as required under 40 CFR §60.48b(c), (d), (e) and (f). The Nitrogen Oxide CEM is required to install a flow rate sensor per the requirements of 40 CFR Part 60 Appendix B: Performance Specification 6.

**Carbon monoxide (CO)** emission shall be monitored continuously by the owner or operator through the use of a CEMS. Therefore, the owner or operator shall install, calibrate, maintain, and operate a CEMS for measuring CO emissions discharged to the atmosphere and record the output of the system. The system shall be designed to meet the 40 CFR 60, Appendix B, Performance Specification 4A (PS4A) and Performance Specification 6 (PS6) requirements. The specifications of 40 CFR 60, Appendix F (Quality Assurance/Quality Control) shall apply.

Appendix F requirements shall be supplemented with a quarterly notice to the Department with the dates of the quarterly cylinder gas audits and annual relative accuracy test audit.

The following data requirements shall apply to all CEMS for non-NSPS emission standards in this permit:

- (1) The CEMS required by this permit shall be operated and data recorded during all periods of operation of the emission unit except for CEM breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.
- (2) The 1-hour average NO<sub>x</sub>, and CO emission rates measured by the CEMS required by this permit shall be used to calculate compliance with the emission standards of this permit. At least 2 data points must be used to calculate each 1-hour average.
- (3) For each hour of missing emission data (NO<sub>x</sub> or CO), the owner or operator shall substitute data by:
  - (i) If the monitor data availability is equal to or greater than 95.0%, the owner or operator shall calculate substitute data by means of the automated data acquisition and handling system for each hour of each missing data period according to the following procedures:
    - (a) For the missing data period less than or equal to 24 hours, substitute the average of the hourly concentrations recorded by a pollutant concentration monitor for the hour before and the hour after the missing data period.
    - (b) For a missing data period greater than 24 hours, substitute the greater of:
      - The 90<sup>th</sup> percentile hourly concentration recorded by a pollutant concentration monitor during the previous 720 quality-assured monitor operating hours; or
      - The average of the hourly concentrations recorded by a pollutant concentration monitor for the hour before and the hour after the missing data period.
  - (ii) If the monitor data availability is at least 90.0% but less than 95.0%, the owner or operator shall calculate substitute data by means of the automated data acquisition and handling system for each hour of each missing data period according to the following procedures:
    - (a) For a missing data period of less than or equal to 8 hours, substitute the average of the hourly concentrations recorded by a pollutant concentration monitor for the hour before and the hour after the missing data period.
    - (b) For the missing data period of more than 8 hours, substitute the greater of:
      - The 95<sup>th</sup> percentile hourly pollutant concentration recorded by a pollutant concentration monitor during the previous 720 quality-assured monitor operating hours; or
      - The average of the hourly concentrations recorded by a pollutant concentration monitor for the hour before and the hour after the missing data period.
  - (iii) If the monitor data availability is less than 90.0%, the owner or operator shall obtain actual emission data by an alternate testing or monitoring method approved by the Department.

Authority for Requirement: DNR Construction Permit 06-A-1183-S6

**Agency Approved Operation & Maintenance Plan Required?** Yes  No

Required for multicyclones following DDGS dryers.

**Facility Maintained Operation & Maintenance Plan Required?** Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?** Yes  No

Operating Requirements with Associated Monitoring and Recordkeeping are CAM equivalent.

Authority for Requirement: 567 IAC 22.108(3)

## Multi Cyclone Agency Operation & Maintenance Plan

This Operations and Maintenance (O&M) Plan pertains to the multicyclones which are part of the process equipment and service Emission Point EP S10.

### **Monitoring Guidelines**

Flint Hills Resources Menlo, LLC makes commitment to take corrective action during period of excursion where the indicators are out of range. A corrective action may include an investigation of the reason for the excursion, evaluation of the situation and necessary follow up action to return operation within the indicator range. An excursion is determined by the averaged discrete data point over a period of time, or the presence of a monitored abnormal condition. An excursion does not necessarily indicate a violation of an applicable requirement. If the corrective action measures fail to return the indicators to the appropriate range, the facility will report the excursion to the department and continue to eliminate the root cause.

### **Monitoring Methods & Corrective Actions**

#### **General**

- Periodic Monitoring is not required during periods of time greater than one day in which the source does not operate.
- Flint Hills Resources Menlo, LLC will maintain a written record of the observation, deficiencies and any action resulting from the inspections.

#### **Continuous**

- Operational personnel will maintain dryer/cyclone systems at optimal operating pressures. Pressure indicators in the dryer drums will be maintained at negative pressure for optimal flow. Corrective action will be taken in the event of the system pressure swings positive (during start-up, shutdown and upset conditions) to return to negative pressures.
- Multiclones have high level switches present, monitored within the DCS to ensure appropriate operation. Operators will systematically shutdown the dryer feed and the dryers in a safe manner when system alarm is activated. Corrective action includes immediate troubleshooting to verify the validity of the high level alarm prior to shutdown of dryers.
- If leaks or abnormal conditions are detected the appropriate measures for remediation will be implemented within eight (8) hours.

#### **Daily**

- Operations personnel will conduct visual inspections of sight glasses on the Thermal Oxidizers which can provide indications of unusual carry over of particulate from the multiclones. If unusual or excessive carry over particulate is observed action will be taken as soon as possible, but no later than 8 hour after the occurrence
- Flint Hills Resources Menlo, LLC will maintain a written record of the observations, deficiencies and any action resulting from the inspection.
- If leaks or abnormal conditions are detected the appropriate measures for remediation will be implemented within eight (8) hours.

**Semi-Annual**

- Inspect the structural components including the cyclone ductwork and hoods for leaks or component failure.
- Flint Hills Resources Menlo, LLC will maintain a written record of the observations, deficiencies and any action resulting from the inspection.
- If leaks or abnormal conditions are detected the appropriate measures for remediation will be implemented within eight (8) hours.

**Annual**

- Inspect the hopper unloading components.
- Check for leaks in the system to ensure the airflow from the dirty side doesn't infiltrate the clean side. Verify that the inlet and outlet ductwork is in good operating condition.
- Check the barrel and collecting tube for deposits and/or excess wear and clean/repair as needed. Dents in the barrel or collecting tube must be removed to ensure proper operation.
- Inspect the cyclone inlet vanes (ramps or spinners) and if necessary clean to ensure they operate according to manufacture specification.
- Flint Hills Resources Menlo, LLC will maintain a written record of the observations, deficiencies and any action resulting from the inspection.
- If leaks or abnormal conditions are detected the appropriate measures for remediation will be implemented before the system is returned to service.

**Record Keeping and Reporting**

- Flint Hills Resources Menlo, LLC will maintain a written or electronic record of all inspections and any action resulting from the inspections.
- Flint Hills Resources Menlo, LLC will keep maintenance and inspection records for five (5) years and will be available upon request.

**Quality Control**

- All instruments and control equipment will be calibrated, maintained, and operated according to the manufacture specifications.

Authority for Requirement: 567 IAC 22.108(3)



Pollutant: Total HAP  
 Emission Limits: 20 ppmv<sup>(2)</sup>  
 Authority for Requirement: DNR Construction Permit 06-A-1185-S6  
 40 CFR 63 Subpart FFFF  
 567 IAC 23.1(4)"cf"

<sup>(2)</sup> Actual limit from the MON MACT (40 CFR 63 Subpart FFFF is 98% or more reduction of total organic HAP or no more than 20 ppmv total organic HAP in the exhaust stream).

**NESHAP Applicability**

Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
A	General Provisions	NA	23.1(4)	§63.1 – §63.15
FFFF	National Emission Standards for Hazardous Air Pollutants: Miscellaneous Organic Chemical Manufacturing	NA	23.4(4)"cf"	§63.4230 – §63.2550

**Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. For each month of operation, the facility shall operate the scrubber according to the parameters (water feed rate, process (make-up) water feed rate, and additive feed rate) that it established during the seasonal performance testing required under Monitoring Requirements to demonstrate compliance with the permitted emission limits.

**Permitted Monthly Scrubber Operating Parameters as Allowed by Season Tested**

Season Tested	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.
Summer (testing shall be conducted in June, July or August)	X	X	X	X	X	X	X	X	X	X	X	X
Winter (testing allowed in any month from October through April)	X	X	X	X						X	X	X

- B. For each day of operation that the plant is operating at a reduced rate, the facility shall operate the scrubber according to the parameters (water feed rate, process (make-up) water feed rate, and the additive feed rate) that it established during the “half-rate” performance testing required under Monitoring Requirements to demonstrate compliance with the permitted emissions limit.
- C. The control device (CE C40) associated with this emission point shall be operated at all times process equipment associated with this emission point is in operation.
- D. As required by 40 CFR §63.2450(e)(1), the owner or operator of this equipment shall comply with the requirements of 40 CFR §63.982(c). This also requires the owner or operator to comply with the requirements of 40 CFR §63.990(b) and 40 CFR §63.990(c) and any other applicable referenced requirement. The owner or operator shall maintain all records required by the NESHAP Subpart FFFF and all applicable referenced requirements.
- E. As required by 40 CFR §63.6(e), the facility shall develop and implement a written startup, shutdown and malfunction plan (SSMP) unless otherwise excluded within the applicable standards.
- F. The owner or operator shall install, operate and maintain equipment necessary to continuously monitor the water feed rate (in gallons per minute) into the scrubber. This equipment shall be installed, operated, and maintained in accordance with the facility’s Operations & Maintenance (O&M) Plan.
  - a. The daily (calendar day) average water feed rate (in gallons per minute) into the scrubber shall be maintained at or above the average value observed during the most recent applicable seasonal operating or operating rate compliance test which demonstrated compliance with all applicable emission limits.
  - b. The facility shall record the permitted scrubbing water flow rate it is utilizing for each month as determined during the most recent seasonal performance test that is being used to demonstrate compliance.
- G. The owner or operator shall install, operate and maintain equipment necessary to continuously monitor the process (make-up) water feed rate (in gallons per minute) into the scrubber. This equipment shall be installed, operated, and maintained in accordance with the facility’s Operations & Maintenance (O&M) Plan.
  - a. The daily (calendar day) average process (make-up) water feed rate (in gallons per minute) into the scrubber shall be maintained at or above the average value observed during the most recent applicable seasonal operating or operating rate compliance test which demonstrated compliance with all applicable emission limits.
  - b. The facility shall record the permitted process (make-up) water flow rate it is utilizing for each month as determined during the most recent seasonal performance test that is being used to demonstrate compliance
- H. The owner or operator shall install, operate and maintain equipment necessary to continuously monitor the additive feed rate into the scrubber. This equipment shall be installed, operated, and maintained in accordance with the facility’s Operations & Maintenance (O&M) Plan.
  - i. The daily (calendar day) average additive feed rate (in milliliters per minute) into the scrubber shall be maintained at or above the average value observed during the most recent applicable seasonal operating or operating rate compliance test which demonstrated compliance with all applicable emission limits.
- I. The owner or operator shall install, operate and maintain equipment necessary to

continuously monitor the pressure drop across the scrubber. This equipment shall be installed, operated, and maintained in accordance with the facility's Operations & Maintenance (O&M) Plan.

- a. The facility shall maintain a daily (calendar day) average differential pressure drop across the wet scrubber that is less than 15 inches water column based on a daily averaging period. The facility shall establish an alarm setting for the purpose of initiating corrective action based on a pressure drop across the wet scrubber greater than 15 inches water column.
- b. The owner or operator shall collect and record differential pressure drop at minimum of once every 15 minutes and calculate and record the average pressure drop across the scrubber based on a daily (calendar day) average.
- c. If the daily (calendar day) average pressure drop is greater than 15 inches of water column, the facility shall record the time, date and actions taken to correct the situation and also when the parameter is back in the acceptable average pressure drop range.
- d. These requirements shall not apply on days that the scrubber or the equipment the scrubber controls is not in operation.

J. The owner or operator shall install, operate and maintain equipment necessary to continuously monitor the scrubbing process (make-up) water outlet temperature from the heat exchanger (i.e., prior to mixing with well water). This equipment shall be installed, operated, and maintained in accordance with the facility's Operations & Maintenance (O&M) Plan.

- a. The facility shall maintain a daily (calendar day) average temperature of the scrubbing process water (measured at the outlet of the heat exchanger) that is no greater than 5°F above the average scrubbing process water temperature recorded during a previous applicable seasonal operating or operating rate performance test that demonstrated compliance with all applicable emission limits.
- b. The owner or operator shall collect and record scrubbing process water temperature at a minimum of once every 15 minutes and calculate and record the daily average scrubbing process water temperature.
- c. If the daily (calendar day) average scrubbing process water temperature exceeds the average scrubbing process water temperature recorded during a previous applicable seasonal operating or operating rate performance test that demonstrated compliance with all applicable emission limitations by more than 5°F, the facility shall record the time, date and actions taken to correct the situation, and the time and date that parameter was returned below the acceptable maximum scrubbing process water temperature.
- d. The facility shall establish an alarm setting for the purpose of initiating corrective action based on a scrubbing process water temperature greater 5°F above the average scrubbing process water temperature recorded during a previous applicable seasonal operating or operating rate performance test that demonstrated compliance.
- e. These requirements shall not apply on days that the scrubber or the equipment the scrubber controls is not in operation.

K. Maintain a copy of the previous performance tests for each scrubber seasonal operating scenario and “half-rate” operating scenario detailing scrubber pressure drop, water feed rate, process (make-up) water feed rate, and additive feed rate measured during each performance test which demonstrated compliance with emission limits.





## **Emission Point ID Number: EP S70**

### Associated Equipment

Associated Emission Unit ID Numbers: EU P70

Emissions Control Equipment ID Number: CE C70

Emissions Control Equipment Description: Baghouse

---

Emission Unit vented through this Emission Point: EU P70

Emission Unit Description: DDGS Cooler

Raw Material/Fuel: Beer Feed

Rated Capacity: 1,675 gal/min

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40%<sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 07-A-295-S3

567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of "no visible emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM<sub>10</sub>)

Emission Limit: 0.67 lb/hr

Authority for Requirement: DNR Construction Permit 07-A-295-S3

Pollutant: Particulate Matter (PM)

Emission Limit: 0.67 lb/hr; 0.1 gr/dscf

Authority for Requirement: DNR Construction Permit 07-A-295-S3

567 IAC 23.4(7)

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit: 2.62 lb/hr

Authority for Requirement: DNR Construction Permit 07-A-295-S3



**Compliance Assurance Monitoring Plan for Flint Hills Resources Menlo, LLC  
Facility located in Menlo, Iowa**

**EP S70 – DDGS Cooler Baghouse**

**I. Background**

A. Emissions Unit

Description: DDGS Cooler (EU P70)

Facility: Flint Hills Resources Menlo, LLC  
Menlo, Iowa

B. Applicable Regulation, Emission Limit, and Monitoring Requirements

Regulation No.: Construction Permit 07-A-295-S3

PM Emission Limit or Standard: 0.67 lb/hr; 0.1 gr/dscf

C. Control Technology

Fabric Filter Baghouse (CE C70)

**II. DDGS Cooler Baghouse Monitoring Approach**

A. Indicator

Pressure drop will be used as the performance indicator.

B. Measurement Approach

The key elements of the monitoring approach, including the indicators to be monitored, indicator ranges, and performance criteria are presented in Table 1.

**Table 4: Monitoring Approach**

<b>I. Indicator</b>	
Indicator	Differential pressure across the baghouse
Measurement / Approach	The pressure drop will be monitored and recorded at least once each day of operation.
<b>II. Indicator Range</b>	
Range	A pressure drop of 0 to 6 inches of water shall be maintained during operation.
Corrective Action	Procedures, system parameters, data trends will be reviewed and the functional operation of the equipment will be assessed to determine the cause of the excursion. Once the cause is identified, a repair or adjustment will be implemented to procedures to address the excursion.
QIP Threshold	An accumulation of excursions outside the indicator range of six or more for a reporting period excluding periods of startup, shutdown and malfunction.
<b>III. Performance Criteria</b>	
Data Representativeness	Pressure drop is measured across the system
Verification of Operational Status	Records of pressure drop readings will be maintained for five years.
QA/QC Practices and Criteria	Calibrate, maintain, and operate instrumentation in accordance with the Facility Operation and Maintenance Plan.
Monitoring Frequency	The pressure drop will be recorded a minimum of once per day during operations.
Data Collection Procedures	The pressure drop will be recorded electronically or manually.
Averaging period	Not applicable.
Record Keeping	Maintain for a period of five years records and corrective actions taken in response to excursions.
Reporting	Number, duration, and cause of any excursion and the corrective action taken.
Frequency	Semiannually.

**III. Justification**

A. Background

PM emissions from the DDGS Cooler (EU S70) are controlled by the DDGS Cooler Baghouse.

B. Rationale for Selection of Performance Indicator

Baghouses operate by collecting particulate on porous fabric bags, thus resulting in a pressure differential across the system. The gas stream is passed through the fabric which results in pressure; too much pressure indicates a possible plugging of the system and too little indicates possible bag breakage. Therefore, pressure drop is the best indicator of baghouse performance.

C. Rationale for Selection of Indicator Level

Baghouses remove dust from a gas stream by passing the stream through a porous fabric. Particles form a porous cake on the fabric that acts as the filtration device. This porous cake is routinely removed and collected and returned to the process. Baghouses are highly efficient for controlling filterable PM. Baghouses are subject to failure if they are not properly operated and maintained. An indicator pressure drop of 0 to 6 inches of water is recommended to achieve the required control efficiency.

The selected QIP threshold for the daily pressure drop is six excursions during a semi-annual reporting period. If the QIP threshold is exceeded during a semi-annual reporting period, a QIP will be developed and implemented.



- Any issues identified during the inspection;
- Any issues addressed during the maintenance activities; and,
- Identification of the staff member performing the maintenance or inspection.

Authority for Requirement: DNR Construction Permits 06-A-1182-S3

**Emission Point Characteristics**

*The emission points shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 40  
 Stack Opening (inches, dia.): 22  
 Exhaust Flow Rate (scfm): 6,500  
 Exhaust Temperature (°F): Ambient  
 Discharge Style: Vertical Unobstructed  
 Authority for Requirement: DNR Construction Permits 06-A-1182-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

- Agency Approved Operation & Maintenance Plan Required?** Yes  No
- Facility Maintained Operation & Maintenance Plan Required?** Yes  No
- Compliance Assurance Monitoring (CAM) Plan Required?** Yes  No

Authority for Requirement: 567 IAC 22.108(3)

**Compliance Assurance Monitoring Plan for Flint Hills Resources Menlo, LLC  
Facility located in Menlo, Iowa**

**EP S90 – DDGS Loadout Baghouse**

**I. Background**

A. Emissions Unit

Description: DDGS Loadout (EU P90)

Facility: Flint Hills Resources Menlo, LLC  
Menlo, Iowa

B. Applicable Regulation, Emission Limit, and Monitoring Requirements

Regulation No.: Construction Permit 06-A-1182-S3

PM Emission Limit or Standard: 0.39 lb/hr; 0.1 gr/dscf

C. Control Technology

Fabric Filter Baghouse (CE C90)

**II. DDGS Storage and Loadout Baghouse Monitoring Approach**

A. Indicator

Pressure drop will be used as the performance indicator.

B. Measurement Approach

The key elements of the monitoring approach, including the indicators to be monitored, indicator ranges, and performance criteria are presented in Table 1.

**Table 5: Monitoring Approach**

<b>I. Indicator</b>	
Indicator	Differential pressure across the baghouse
Measurement / Approach	The pressure drop will be monitored and recorded at least once each day of operation.
<b>II. Indicator Range</b>	
Range	A pressure drop of 0 to 6 inches of water shall be maintained during operation.
Corrective Action	Procedures, system parameters, data trends will be reviewed and the functional operation of the equipment will be assessed to determine the cause of the excursion. Once the cause is identified, a repair or adjustment will be implemented to procedures to address the excursion.
QIP Threshold	An accumulation of excursions outside the indicator range of six or more for a reporting period excluding periods of startup, shutdown and malfunction.
<b>III. Performance Criteria</b>	
Data Representativeness	Pressure drop is measured across the system
Verification of Operational Status	Records of pressure drop readings will be maintained for five years.
QA/QC Practices and Criteria	Calibrate, maintain, and operate instrumentation in accordance with the Facility Operation and Maintenance Plan.
Monitoring Frequency	The pressure drop will be recorded a minimum of once per day during operations.
Data Collection Procedures	The pressure drop will be recorded electronically or manually.
Averaging period	Not applicable.
Record Keeping	Maintain for a period of five years records and corrective actions taken in response to excursions.
Reporting	Number, duration, and cause of any excursion and the corrective action taken.
Frequency	Semiannually.

### **III. Justification**

#### **A. Background**

PM emissions from the DDGS Loadout (EU P90) are controlled by the DDGS Storage and Loadout Baghouse.

#### **Rationale for Selection of Performance Indicator**

Baghouses operate by collecting particulate on porous fabric bags, thus resulting in a pressure differential across the system. The gas stream is passed through the fabric which results in pressure; too much pressure indicates a possible plugging of the system and too little indicates possible bag breakage. Therefore, pressure drop is the best indicator of baghouse performance.

B. Rationale for Selection of Indicator Level

Baghouses remove dust from a gas stream by passing the stream through a porous fabric. Particles form a porous cake on the fabric that acts as the filtration device. This porous cake is routinely removed and collected and returned to the process. Baghouses are highly efficient for controlling filterable PM. Baghouses are subject to failure if they are not properly operated and maintained. An indicator pressure drop of 0 to 6 inches of water is recommended to achieve the required control efficiency.

The selected QIP threshold for the daily pressure drop is six excursions during a semi-annual reporting period. If the QIP threshold is exceeded during a semi-annual reporting period, a QIP will be developed and implemented.

## **Emission Point ID Number: EP SEP 22**

### Associated Equipment

Associated Emission Unit ID Numbers: EU F50  
Emissions Control Equipment ID Number: CE F50  
Emissions Control Equipment Description: Flare (13.9 MMBtu/hr)

---

Emission Unit vented through this Emission Point: EU F50  
Emission Unit Description: Product Loadout & Vapor Recovery  
Raw Material/Fuel: Ethanol/Natural Gas  
Rated Capacity: 2,650 gal/min (Total Pump Capacity)

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1190-S4  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedence of the indicator opacity of "No Visible Emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedence. If exceedences continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit: 0.20 lb/hr; 0.1 gr/dscf

Authority for Requirement: DNR Construction Permit 06-A-1190-S4  
567 IAC 23.3(2)"a"

Pollutant: Sulfur Dioxide (SO<sub>2</sub>)

Emission Limit(s): 500 ppmv

Authority for Requirement: DNR Construction Permit 06-A-1190-S4  
567 IAC 23.3(3) "e"

Pollutant: Nitrogen Oxide (NO<sub>x</sub>)

Emission Limit: 1.27 tons/yr

Authority for Requirement: DNR Construction Permit 06-A-1190-S4

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit: 3.79 tons/yr

Authority for Requirement: DNR Construction Permit 06-A-1190-S4

Pollutant: Carbon Monoxide (CO)  
 Emission Limit: 5.96 tons/yr  
 Authority for Requirement: DNR Construction Permit 06-A-1190-S4

**NESHAP Applicability**

Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
A	General Provisions	NA	23.1(4)	§63.1 – §63.15
FFFF	National Emission Standards for Hazardous Air Pollutants: Miscellaneous Organic Chemical Manufacturing	Group 2 transfer racks	23.1(4)"cf"	§63.4230 – §63.2550

**Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. The control device (CE F50) associated with this emission point shall be operated at all times product is loaded through the rail or truck loadout.
- B. The flare shall be limited to operating for not more than 2600 hours per twelve-month rolling period. (NOTE: the pilot light is allowed to operate 8760 hours per year).
  - i. On a monthly basis, the owner or operator shall record the number of hours the flare is operated.
  - ii. The owner or operator shall monthly calculate and record the rolling 12-month total number of hours the flare is operated.
- C. The total amount of ethanol (denatured and undenatured) transported through the truck loading and rail loading shall not exceed 140,000,000 gallons per twelve-month rolling period.
  - i. On a monthly basis, the owner or operator shall record the total amount of ethanol (denatured and undenatured) loaded through the truck & rail loadout, in gallons.
  - ii. The owner or operator shall monthly calculate and record the rolling 12-month total amount of ethanol (denatured and undenatured) loaded through the truck & rail loadout, in gallons.
- D. The total amount of switch-loading at the truck loadout shall not exceed 2,640,000 gallons per twelve-month rolling period. Switch-loading is not allowed at the rail loadout.
  - i. On a monthly basis, the owner or operator shall record the amount of product switch-loaded through the truck loadout, in gallons.
  - ii. The owner or operator shall monthly calculate and record the rolling 12-month total amount of product switch-loaded through the truck loadout, in gallons.
- E. The flare (CE F50) shall meet the following requirements:
  - i. Be designed for and operated with no visible emissions except for periods not to exceed a total of five (5) minutes during any two (2) consecutive hours;
  - ii. Be operated with a flame present at all times product is being loaded;
  - iii. Be designed to ensure smokeless design; and,

- iv. The presence of a flare pilot flame shall be monitored using a thermocouple or any other equivalent device to detect the presence of a flame.
- F. The control equipment, CE F50, shall be operated and maintained according to the facility’s Operations & Maintenance (O&M) Plan.
- G. The owner or operator shall comply with the applicable requirements in 40 CFR Part 63, Subpart FFFF – *National Emission Standards for Hazardous Air Pollutants for Miscellaneous Organic Chemical Manufacturing* [§63.2430 - §63.2550].
- H. The facility shall maintain a log of all maintenance and inspection activities performed on the control equipment, CE F50. This log shall include, but is not limited to:
  - i. The date any inspection and/or maintenance was performed on the emission unit and/or control equipment;
  - ii. Any issue(s) identified during the inspection and the date each issue(s) was resolved;
  - iii. Any issue(s) addressed during the maintenance activities and the date each issue(s) was resolved; and,
  - iv. Identification of the staff member performing the inspection or maintenance activity.

Authority for Requirement: DNR Construction Permit 06-A-1190-S4

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): 30

Stack Opening, (inches, dia.): 60

Exhaust Flow Rate (scfm): 34,000

Exhaust Temperature (°F): 2000

Discharge Style: Vertical Unobstructed

Authority for Requirement: DNR Construction Permit 06-A-1190-S4

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)



Pollutant: Carbon Monoxide (CO)

Emission Limit(s): 1.77 tons/yr <sup>(2)</sup>

Authority for Requirement: DNR Construction Permit 07-A-296-S2

<sup>(2)</sup>TPY emission limits are based on operating limits.

**Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

Operating limits for this emission unit shall be:

- A. The flare shall be limited to operating 1752 hours per twelve-month rolling period.  
(NOTE: the pilot light is allowed to operate 8760 hours per year).
- B. The flare (CE 11) shall:
  - Be designed for and operated with no visible emissions except for periods not to exceed a total of five (5) minutes during any two (2) consecutive hours;
  - Be operated with a flame present at all times biogas is routed to the flare;
  - Be designed to ensure smokeless operation;
  - The presence of a flare pilot flame shall be monitored using a thermocouple or any other equivalent device to detect the presence of a flame.
- C. The control equipment shall be inspected and maintained according to manufacturer's recommendations

Reporting and Recordkeeping shall be:

- A. At the end of each month, record the number of hours the flare operated over the previous month.
- B. At the end of each month, record the number of hours the flare operated over the previous twelve (12) months.
- C. The owner or operator shall monitor the presence of a flare pilot flame using a thermocouple or any other equivalent device to detect the presence of a flame.
- D. The owner or operator shall keep records of control equipment inspections and repairs.

Authority for Requirement: DNR Construction Permit 07-A-296-S2

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): 34

Stack Opening, (inches, dia.): 24

Exhaust Flow Rate (scfm): 1,500

Exhaust Temperature (°F): 1800

Discharge Style: Vertical unobstructed

Authority for Requirement: DNR Construction Permit 07-A-296-S2

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the

temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Operating Requirements with Associated Monitoring and Recordkeeping are CAM equivalent.

Authority for Requirement: 567 IAC 22.108(3)

**Emission Point ID Number: EP S80**

Associated Equipment

Associated Emission Unit ID Numbers: EU P80  
Emissions Control Equipment ID Number: None  
Emissions Control Equipment Description: Drift Eliminators (0.005% drift loss)

---

Emission Unit vented through this Emission Point: EU P80  
Emission Unit Description: Cooling Tower (4 cells)  
Raw Material/Fuel: Water  
Rated Capacity: 3,480,000 gallons per hour total

**Applicable Requirements**

**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1192-S3  
567 IAC 23.3(2) "d"

<sup>(1)</sup> An exceedance of the indicator opacity of 10% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM<sub>10</sub>)

Emission Limit: 3.63 lb/hr

Authority for Requirement: DNR Construction Permit 06-A-1192-S3

Pollutant: Particulate Matter (PM)

Emission Limit: 3.63 lb/hr; 0.1 gr/dscf

Authority for Requirement: DNR Construction Permit 06-A-1192-S3  
567 IAC 23.3(2) "a"

**Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

**Operating Limits**

- A. The circulating water in the cooling tower shall not exceed 2500 parts per million (ppm) total dissolved solids (TDS). Monitoring of the TDS shall be conducted on a monthly schedule.

- B. The cooling tower and drift eliminator shall be operated and maintained per the manufacturer's specifications and instructions.
- C. The owner/operator shall use no water treatment chemicals that contain chromium compounds.

**Reporting & Record keeping**

- A. Maintain records on-site of the TDS concentration in the cooling tower circulating water. Records shall also be kept of the dates of measurement and the methods used to determine the concentration of the TDS in the cooling water.
- B. Maintain records of all maintenance and repair to the cooling tower and drift eliminator.
- C. Maintain MSDS for all water treatment chemicals used at the facility.

Authority for Requirement: DNR Construction Permit 06-A-1192-S3

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 39.83

Stack Opening (inches, dia.): 360

Exhaust Flow Rate (scfm): 4,088,000

Exhaust Temperature (°F): 84

Discharge Style: Vertical Unobstructed

Authority for Requirement: DNR Construction Permit 06-A-1192-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)



**Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

**Operating Limits**

A. The owner or operator shall follow the applicable standards of Subpart Kb, 40 CFR 60.112b(a)(1), and inspect as required in 40 CFR 60.113b(a).

**Reporting & Record keeping**

A. The owner or operator shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the lifetime of the source.

B. The owner or operator shall follow the applicable recordkeeping and reporting standards of Subpart Kb, 40 CFR 60.115b through 60.116b.

Authority for Requirement: See Table: Storage Tanks

**Emission Point Characteristics**

*These emission points shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): NA

Stack Opening, (inches, dia.): NA

Exhaust Flow Rate (scfm): See Note

Exhaust Temperature (°F): Ambient

Discharge Style: NA

Authority for Requirement: See Table: Storage Tanks

Note: The air flow from this unit is the result of working and breathing losses. As a result the air flow will vary dependent on ambient and operating conditions.

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Number: EP T64

### Associated Equipment

Associated Emission Unit ID Numbers: EU T64  
 Emissions Control Equipment ID Number: CE T64  
 Emissions Control Equipment Description: Internal Floating Roof

Emission Unit vented through this Emission Point: EU T64  
 Emission Unit Description: Denaturant Storage Tank  
 Raw Material/Fuel: Denaturant  
 Rated Capacity: 200,000 gallons

### Applicable Requirements

#### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

*The emissions from this emission point shall not exceed the levels specified below.*

There are no emission limits at this time.

### NSPS and NESHAP Applicability

EU ID	Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
EU T64	A	General Provisions	NA	23.1(2)	§60.1 – §60.19
	Kb	NSPS for Volatile Organic Liquid Storage Vessels for which Construction, Reconstruction, or Modification commenced after July 23, 1984	Capacity > 19,800 gallons	23.1(2)"ddd"	§60.110b - §60.117b

Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
A	General Provisions	NA	23.1(4)	§63.1 – §63.15
FFFF	National Emission Standards for Hazardous Air Pollutants: Miscellaneous Organic Chemical Manufacturing	NA	23.1(4)"cf"	§63.4230 – §63.2550

### **Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. The owner or operator shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the lifetime of the source.
- B. The owner or operator shall follow the applicable standards of Subpart Kb, 40 CFR 60.112b(a)(1), and inspect as required in 40 CFR 60.113b(a).
- C. The owner or operator shall follow the applicable recordkeeping and reporting standards of Subpart Kb, 40 CFR 60.115b through 60.116b.
- D. As required by 40 CFR 63.2535(c), the owner or operator of this equipment shall be in compliance with Subpart FFFF if it is in compliance with the provisions of 40 CFR 60, Subpart Kb, except that the owner must also comply with the monitoring, recordkeeping and reporting requirements of NESHAP Subpart FFFF.
- E. As required by 40 CFR 63.6(e), the facility shall develop and implement a written startup, shutdown and malfunction plan (SSMP) unless otherwise excluded in the applicable standards.

Authority for Requirement: DNR Construction Permit 06-A-1197-S3

### **Emission Point Characteristics**

*These emission points shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): NA

Stack Opening, (inches, dia.): NA

Exhaust Flow Rate (scfm): Working and Breathing Losses

Exhaust Temperature (°F): Ambient

Discharge Style: NA

Authority for Requirement: DNR Construction Permit 06-A-1197-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: EP FP**

### Associated Equipment

Associated Emission Unit ID Numbers: EU FP

---

Emission Unit vented through this Emission Point: EU FP  
Emission Unit Description: Fire Water Pump  
Raw Material/Fuel: Diesel  
Rated Capacity: 300 bhp

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1191-S3  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM<sub>10</sub>)

Emission Limit: 1.0 lb/hr

Authority for Requirement: DNR Construction Permit 06-A-1191-S3

Pollutant: Particulate Matter (PM)

Emission Limit: 1.0 lb/hr

Authority for Requirement: DNR Construction Permit 06-A-1191-S3

Pollutant: Sulfur Dioxide (SO<sub>2</sub>)

Emission Limit: 0.93 lb/hr

Authority for Requirement: DNR Construction Permit 06-A-1191-S3

Pollutant: Nitrogen Oxide (NO<sub>x</sub>)

Emission Limit: 14.2 lb/hr

Authority for Requirement: DNR Construction Permit 06-A-1191-S3

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit: 1.13 lb/hr

Authority for Requirement: DNR Construction Permit 06-A-1191-S3

Pollutant: Carbon Monoxide (CO)  
Emission Limit: 3.06 lb/hr  
Authority for Requirement: DNR Construction Permit 06-A-1191-S3

**NSPS and NESHAP Applicability**

This engine is subject to 40 CFR Part 60 NSPS Subpart III – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (IAC 23.1(2)"yyy"). The engine is a fire pump engine.

In accordance with §60.4202(d), the engine must comply with the emissions standards for fire pumps from §60.4205 (c) and §60.4202 (d). The emission standards that the engine must be certified by the manufacturer to meet are:

Pollutant	Emission Standard	Basis
Particulate Matter (PM)	0.54 grams/kW-hr	§ 89.112 Table 1
NMHC <sup>1</sup> + NOx	10.5 grams/kW-hr	§ 89.112 Table 1
Carbon Monoxide (CO)	3.5 grams/kW-hr	§ 89.112 Table 1
Opacity – acceleration mode	20%	§ 89.113 (a)(1)
Opacity – lugging mode	15%	§ 89.113 (a)(2)
Opacity – peaks in acceleration or lugging modes	50%	§ 89.113 (a)(3)

<sup>1</sup> Non-methane hydrocarbon

In accordance with §60.4211(c), the owner or operator must comply with the required NSPS emissions standards by purchasing an engine certified by its manufacturer to meet the applicable emission standards for the same model year and engine power. The engine must be installed and configured to the manufacturer’s specifications. Provided these requirements are satisfied, no further demonstration of compliance with the emission standards from §60.4205 (b) and §60.4202 (a)(2) is required. However, if the engine is not installed, configured, operated, and maintained according to the manufacturer’s emission-related written instructions, a compliance demonstration is required in accordance with §60.4211(g).

Authority for Requirement: DNR Construction Permit 06-A-1191-S3  
40 CFR Part 60 Subpart III  
567 IAC 23.1(2)"yyy"

This engine is of the source type regulated by the National Emission Standard for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines (40 CFR Part 63, Subpart ZZZZ). The engine is a new reciprocating internal combustion engine located at a major source of HAP, and it is rated less than or equal 500 HP. In accordance with §63.6590 (c)(6), the engine must comply with the

requirements of Subpart ZZZZ by meeting the requirements of NSPS subpart IIII. No further requirements apply to this engine under Subpart ZZZZ.

Authority for Requirement: DNR Construction Permit 06-A-1191-S3  
40 CFR Part 63 Subpart ZZZZ  
567 IAC 23.1(4)"cz"

### **Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

#### **Operating Limits**

- A. This engine is limited to burning diesel fuel oil that meets the requirements of Condition D below.
- B. This engine is limited to operating a maximum of 100 hours in any rolling 12-month period.
- C. This engine is limited to operate as an emergency stationary internal combustion engine as defined in §60.4219 and in accordance with §60.4211. There is no time limit on the use of the engine in emergency situations provided that the annual hourly limit established in Condition B is not exceeded. In accordance with §60.4211, the engine is limited to operate a maximum of 100 hours per year for maintenance checks and readiness testing.
- D. In accordance with §60.4207(b), the diesel fuel oil burned in this engine shall meet the following specifications from 40 CFR 80.510(b) for nonroad diesel fuel:
  - i. a maximum sulfur content of 15 ppm (0.0015%) by weight; and
  - ii. a minimum cetane index of 40 or a maximum aromatic content of 35 percent by volume.
- E. In accordance with §60.4209(a), the engine shall be equipped with a non-resettable hour meter.
- F. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in §60.4211(g).
- G. In accordance with §60.4211(a), this engine shall be operated and maintained in accordance with the manufacturer's emission-related written instructions. The owner or operator may only change emission-related engine settings that are permitted by the manufacturer.

#### **Reporting & Record keeping**

- A. The owner or operator shall maintain the following monthly records:
  - i. the number of hours that the engine operated for maintenance checks and readiness testing;
  - ii. the number of hours that the engine operated for allowed non-emergency operations;
  - iii. the total number of hours that the engine operated; and
  - iv. the rolling 12-month total amount of the number of hours that the engine operated.
- B. The owner or operator shall maintain the following annual records:
  - i. the number of hours that the engine operated for maintenance checks and readiness testing; and
  - ii. the number of hours that the engine operated for allowed non-emergency operations.
- C. The owner or operator of the engine shall comply with the requirements of condition D listed above by one of the following methods:

- i. have the fuel supplier certify that the fuel delivered meets the definition of non-road diesel fuel as defined in 40 CFR 80.510(b);
- ii. obtain a fuel analysis from the supplier showing the sulfur content and cetane index or aromatic content of the fuel delivered; or
- iii. perform an analysis of the fuel to determine the sulfur content and cetane index or aromatic content of the fuel received.

Authority for Requirement: DNR Construction Permit 06-A-1191-S3

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 10

Stack Opening (inches, dia.): 5

Exhaust Flow Rate (scfm): 750

Exhaust Temperature (°F): 770

Discharge Style: Horizontal

Authority for Requirement: DNR Construction Permit 06-A-1191-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

**Emission Point ID Number: EP F110**

Associated Equipment

Associated Emission Unit ID Number: EU F110

Emissions Control Measure Description: Leak Detection and Repair (LDAR)

Emission Unit vented through this Emission Point: EU F110

Emission Unit Description: Fugitive Emissions from Equipment Leaks

Raw Material/Fuel: Equipment Leaks

**Applicable Requirements**

**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: VOC

Emission Limit: 12.28 tons/yr

Authority for Requirement: DNR Construction Permit 06-A-1193-S3

**NSPS and NESHAP Applicability**

EU ID	Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
EU F110	A	General Provisions	NA	23.1(2)	§60.1 – §60.19
	VVa	New Source Performance Standard for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006	NA	23.1(2)"nn"	§60.480a - §60.489a

Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
A	General Provisions	NA	23.1(4)	§63.1 – §63.15
FFFF	National Emission Standards for Hazardous Air Pollutants: Miscellaneous Organic Chemical Manufacturing	NA	23.1(4)"cf"	§63.4230 – §63.2550

### **Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

### **Operating Limits**

- A. The owner/operator shall comply with all requirements of the New Source Performance Standard (NSPS) 40 CFR 60 Subpart VVa.
- B. The owner/operator shall comply with all requirements of the National Emission Standard for Hazardous Air Pollutants (NESHAP) for Miscellaneous Organic Chemical Manufacturing 40 CFR 63 Subpart FFFF and all referenced subparts as applicable.

### **Reporting & Record keeping**

- A. From each months leak detection tracking information determine the following for each component type:
  - i. The fraction of sources that were repaired the previous month that were found to be leaking this month.
  - ii. The fraction of sources that were successfully repaired after being found to leaking in the previous months monitoring.
  - iii. The fraction of sources that were found to not be leaking during the previous months monitoring that were found to be leaking during this month's monitoring.
- B. Using the information collected in A. above, determine the control efficiency of the leak detection and repair program as outlined in EPA's document 453/R-95-017 titled Protocol for Equipment Leak Emission Estimates (page 5-54 through 5-57) Control efficiencies listed in table 5.2 (page 5-9) may be assumed for those components listed. If these control efficiencies are assumed, the information required by A. above need not be recorded for that component type.
- C. Using the information collected above, determine the VOC emissions over the previous month from the facility using the calculation methods outlined in EPA's document 453/R-95-017 titled Protocol for Equipment Leak Emission Estimates (page 2-11).
- D. At the end of each month, record the total VOC emissions over the previous month from the facility by adding the emissions totals for each section as determined in C.
- E. At the end of each month, record the total VOC emissions over the previous twelve (12) months as determined in D above.
- F. The owner/operator shall maintain all records required by the New Source Performance Standard and outlined in 40 CFR 60 Subpart VVa.
- G. The owner/operator shall maintain all records required by the National Emission Standard for Hazardous Air Pollutants (NESHAP) 40 CFR 63 Supbart FFFF and all applicable referenced subparts.

Authority for Requirement: DNR Construction Permit 06-A-1193-S3

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: EP F120**

### Associated Equipment

Associated Emission Unit ID Numbers: EU F120

Emissions Control Measure Description: Sweeping/Flushing

---

Emission Unit vented through this Emission Point: EU F120

Emission Unit Description: Truck Traffic on Plant Roads

Raw Material/Fuel: Dust from Truck Traffic

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): No Visible Emissions <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1198-S3  
567 IAC 23.3(2)"c"

<sup>(1)</sup>The owner/operator shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond lot line of the property.

Pollutant: Particulate Matter (PM<sub>2.5</sub>)

Emission Limit: 0.27 tons/yr <sup>(2)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1198-S3

Pollutant: Particulate Matter (PM<sub>10</sub>)

Emission Limit: 1.15 tons/yr <sup>(2)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1198-S3

Pollutant: Particulate Matter (PM)

Emission Limit: 5.83 tons/yr <sup>(2)</sup>

Authority for Requirement: DNR Construction Permit 06-A-1198-S3

<sup>(2)</sup>Emissions are limited based on the average vehicle weight, silt content, and vehicle miles traveled. See Operating Requirements for compliance demonstration with the silt loading rate.

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. All haul roads at the facility shall be paved.
- B. Truck traffic on the haul road shall not exceed 10 mph. The speed limit shall be posted on the haul road.
- C. Any spills on the road shall be cleaned up immediately.

- D. Cleaning of the haul roads shall be done at least three days per week, weather permitting. If sweeping cannot be accomplished because the ambient air temperature (as measured at the facility during daylight operating hours) will be less than 35° F (1.7° C) or road conditions due to weather could create hazardous driving conditions (i.e., completely covered with snow and/or ice), then the sweeping shall be postponed and accomplished as soon after the scheduled date as the conditions preventing the sweeping have abated.
- i. Sweeping need not occur when a rain gauge located at the site indicates that at least 0.2 inches of precipitation has occurred within the preceding 24-hr time period or the paved road(s) will not be used for that day.
  - ii. If more than 0.2 inches of rainfall occurs during the 24-hour period preceding scheduled sweeping and sweeping is not performed under D.i., it may be assumed that the surfaces have been sufficiently cleaned and that day shall be counted as sweeping occurring.
  - iii. The owner or operator shall record the frequency of sweeping performed on the haul roads. If the roads are not swept due to weather, a written record must be kept on-site outlining the conditions.
  - iv. The owner or operator shall record the type of cleaning (i.e. sweeping, washing, rainfall event, etc.) performed on the haul road.
  - v. Sweeping need not occur if the plant does not receive any truck traffic that day (i.e., during a shutdown, on a weekend, etc.).
  - vi. No more than two days with truck traffic shall occur between sweeping, except as specified in Condition D.i through D.v.
- E. The haul road surface silt loading shall not exceed 0.4 g/m<sup>2</sup>.
- F. Performance testing on the haul road surface silt loading shall be completed on an annual basis. For each performance test, silt loading sampling shall be done for at least 3 different locations. The three sampled locations shall then be averaged to determine the silt loading average results. Performance testing shall be completed prior to sweeping. Should any annual test exceed 90% of 0.4 g/m<sup>2</sup> (0.36 g/m<sup>2</sup>), the facility shall complete silt load testing on a quarterly basis beginning the next quarter after the test that exceeded 0.36 g/m<sup>2</sup>. Quarterly testing shall continue until 8 consecutive tests are less than 0.36 g/m<sup>2</sup>, after which annual testing shall resume.
- G. The plant shall maintain a log for the haul roads that show the following:
- a. The silt content of the road for that month based on annual testing;
  - b. The date of performance testing;
  - c. The vehicle miles traveled (VMT) for that month;
  - d. Each day record whether or not sweeping was accomplished; and,
  - e. The operator's initials.

Authority for Requirement: DNR Construction Permit 06-A-1198-S3

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: EP F130**

### Associated Equipment

Associated Emission Unit ID Numbers: EU F130

---

Emission Unit vented through this Emission Point: EU F130  
Emission Unit Description: WDGS Storage and Loadout (Wet Cake)  
Raw Material/Fuel: WDGS  
Rated Capacity: 258,238 tons/yr

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 07-A-298-S1  
567 IAC 23.3(2) "d"

<sup>(1)</sup> An exceedance of the indicator opacity of "no visible emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Fugitive Dust

Emission Limit: No person shall allow, cause or permit any materials to be handled, transported or stored; or a building, its appurtenances or a construction haul road to be used, constructed, altered, repaired or demolished, without taking reasonable precautions to prevent a nuisance. All persons shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond the lot line of the property on which the emissions originate.

Authority for Requirement: 567 IAC 23.3(2)"c"

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

#### **Operating Limits**

A. Total wet cake production (WDGS) shall not exceed 258,238 tons per twelve-month rolling period.

**Reporting and Recordkeeping**

- A. At the end of each month, record the amount of WDGS produced over the previous month.
- B. At the end of each month, record the amount of WDGS produced over the previous twelve (12) months.

Authority for Requirement: DNR Construction Permit 07-A-298-S1

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: EP S150**

### Associated Equipment

Associated Emission Unit ID Number: EU S150

---

Emission Unit vented through this Emission Point: EU S150  
Emission Unit Description: Whole Stillage Tank  
Raw Material/Fuel: Whole Stillage  
Rated Capacity: 180,000 gallons

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 14-A-417  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of "no visible emissions" will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit: 2.68 lb/hr

Authority for Requirement: DNR Construction Permit 14-A-417

#### **Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 56

Stack Opening (inches, dia.): 12

Exhaust Flow Rate (scfm): See Note

Exhaust Temperature (°F): 175

Discharge Style: Downward

Authority for Requirement: DNR Construction Permit 14-A-417

Note: Exhaust flow from this unit is the result of the standing and working losses from the tank.

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall

submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: EP S160**

### Associated Equipment

Associated Emission Unit ID Number: EU S160

---

Emission Unit vented through this Emission Point: EU S160

Emission Unit Description: Thin Stillage Tank

Raw Material/Fuel: Thin Stillage

Rated Capacity: 374,000 gallons

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40% <sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 14-A-418  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of "no visible emissions" will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit: 4.22 lb/hr

Authority for Requirement: DNR Construction Permit 14-A-418

#### **Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 57.67

Stack Opening (inches, dia.): 12

Exhaust Flow Rate (scfm): See Note

Exhaust Temperature (°F): 140

Discharge Style: Downward

Authority for Requirement: DNR Construction Permit 14-A-418

Note: Exhaust flow from this unit is the result of the standing and working losses from the tank.

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall

submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

**Emission Point ID Number: EP F22**

Associated Equipment

Associated Emission Unit ID Numbers: EU F22

---

Emission Unit vented through this Emission Point: EU F22  
Emission Unit Description: Open Transportation Devices  
Raw Material/Fuel: Ethanol Loading Fugitives  
Rated Capacity: NA

**Applicable Requirements**

**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity <sup>(1)</sup>

Emission Limit(s): No Visible Emissions

Authority for Requirement: DNR Construction Permit 14-A-419  
567 IAC 23.3(2)"c"

<sup>(1)</sup>The permit holder shall take all reasonable precautions to prevent visible emissions from crossing the property line of this facility.

**Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

**Operating Limits**

- A. The owner/operator shall develop and follow a best management practice to minimize emission from open transportation vessels. This best management practice shall at a minimum outline the action steps necessary to minimize the amount of time a vessel is open without being connected to a vapor collection system or a system that would draw air into the vessel.
- B. No product shall be loaded into a vessel prior to the connection of the vapor collection system to the vessel.

**Reporting & Record keeping**

- A. Maintain a copy of the best management practice available for review.

Authority for Requirement: DNR Construction Permit 14-A-419

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Emissions from this unit are fugitive emissions from open transportation devices (IE Railcars or tanker trucks). These emissions occur when the railcar or truck tank is opened for loading or unloading of product or material to or from the tank. This permit only accounts for the time between opening the tank and connection of the vapor collection system to the tank for loading operations.

Authority for Requirement: DNR Construction Permit 14-A-419

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

**Emission Point ID Number: EP S33**

Associated Equipment

**Table: Grain Receiving and Storage**

<b>Emission Unit</b>	<b>Emissions Unit Description</b>	<b>Raw Material/Fuel</b>	<b>Rated Capacity</b>	<b>Control Equipment</b>
71	Grain Receiving #2	Grain	30,000 bu/hr	Baghouse (CE C33)
72	Grain Elevator #3		30,000 bu/hr	
73	Grain Bin #3		1,927,775 bu	

**Applicable Requirements**

**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity <sup>(1) (2)</sup>

Emission Limit(s): 0 %

Authority for Requirement: DNR Construction Permit 18-A-074  
40 CFR 60 Subpart DD  
567 IAC 23.1(2)"ooo"

<sup>(1)</sup> Opacity limit on EP-S33 in accordance with 40 CFR §60.302(b)(2).

<sup>(2)</sup> In accordance with 40 CFR §60.302(c)(1), the opacity from uncaptured emissions from the grain receiving pit (EU-71) shall not exceed 5%.

Pollutant: Particulate Matter (PM<sub>10</sub>)

Emission Limit: 1.01 lb/hr

Authority for Requirement: DNR Construction Permit 18-A-074

Pollutant: Particulate Matter (PM) (State)

Emission Limit: 1.01 lb/hr; 0.1 gr/dscf

Authority for Requirement: DNR Construction Permit 18-A-074  
567 IAC 23.4(7)

Pollutant: Particulate Matter (PM) (Federal)

Emission Limit: 0.01 gr/dscf <sup>(3)</sup>

Authority for Requirement: DNR Construction Permit 18-A-074  
40 CFR 60 Subpart DD  
567 IAC 23.1(2)"ooo"

<sup>(3)</sup> According to 40 CFR §60.302(b)(1), 0.023 g/dscm = 0.01 gr/dscf

**NSPS Applicability**

EU ID	Subpart	Title	Type	State Reference (567 IAC)	Federal Reference (40 CFR)
EU-71	A	General Provisions	NA	23.1(2)	§60.1 – §60.19
EU-72 EU-73	DD	Stands of Performance for Grain Elevators	NA	23.1(2)"ooo"	§60.300 – §60.304

**Operating Requirements with Associated Monitoring and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. The owner or operator shall maintain the Baghouse (CE C33) according to the facility’s (Facility ID: 39-06-002) operation and maintenance plan. The owner or operator shall maintain a log of all maintenance and inspection activities performed on the Baghouse (CE C33). The owner or operator shall perform an inspection of the Baghouse (CE C33) at least once a year. This log shall include, but is not necessarily limited to:
  - a. The date any inspection and/or maintenance was performed on the Baghouse (CE C33);
  - b. Any issues identified during the inspection and the date each issue was resolved;
  - c. Any issues addressed during the maintenance activities and the date each issue was resolved; and
  - d. Identification of the staff member performing the maintenance or inspection.

Authority for Requirement: DNR Construction Permit 18-A-074

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height (ft, from the ground): 109

Stack Opening (inches, dia.): 30

Exhaust Flow Rate (scfm): 23,500

Exhaust Temperature (°F): Ambient

Discharge Style: Vertical unobstructed

Authority for Requirement: DNR Construction Permit 18-A-074

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

# Compliance Assurance Monitoring Plan for Flint Hills Resources Menlo, LLC Facility located in Menlo, Iowa

## EP S33 – Grain Receiving and Storage #3 Baghouse

### I. Background

#### A. Emissions Unit

Description: Grain Receiving #2, Grain Elevator #3, Grain Bin #3 (EU 71-73)

Facility: Flint Hills Resources Menlo, LLC  
Menlo, Iowa

#### B. Applicable Regulation, Emission Limit, and Monitoring Requirements

Regulation No.: Construction Permit 18-A-074

PM Emission Limit or Standard: 1.01 lb/hr; 0.01 gr/dscf

#### C. Control Technology

Fabric Filter Baghouse (CE C33)

### II. DDGS Cooler Baghouse Monitoring Approach

#### A. Indicator

Pressure drop will be used as the performance indicator.

#### B. Measurement Approach

The key elements of the monitoring approach, including the indicators to be monitored, indicator ranges, and performance criteria are presented in Table 1.

**Table 6: Monitoring Approach**

<b>I. Indicator</b>	
Indicator	Differential pressure across the baghouse
Measurement / Approach	The pressure drop will be monitored and recorded at least once each day of operation.
<b>II. Indicator Range</b>	
Range	A pressure drop of 0 to 6 inches of water shall be maintained during operation.
Corrective Action	Procedures, system parameters, data trends will be reviewed and the functional operation of the equipment will be assessed to determine the cause of the excursion. Once the cause is identified, a repair or adjustment will be implemented to procedures to address the excursion.
QIP Threshold	An accumulation of excursions outside the indicator range of six or more for a reporting period excluding periods of startup, shutdown and malfunction.
<b>III. Performance Criteria</b>	
Data Representativeness	Pressure drop is measured across the system
Verification of Operational Status	Records of pressure drop readings will be maintained for five years.
QA/QC Practices and Criteria	Calibrate, maintain, and operate instrumentation in accordance with the Facility Operations and Maintenance Plan.
Monitoring Frequency	The pressure drop will be recorded a minimum of once per day during operations.
Data Collection Procedures	The pressure drop will be recorded electronically or manually.
Averaging period	Not applicable.
Record Keeping	Maintain for a period of five years records and corrective actions taken in response to excursions.
Reporting	Number, duration, and cause of any excursion and the corrective action taken.
Frequency	Semiannually.

**III. Justification**

A. Background

PM emissions from the Grain Receiving 2, Grain Elevator 3, and Grain Bin 3 (EU 71-73) are controlled by the Grain Receiving and Storage #3 Baghouse.

B. Rationale for Selection of Performance Indicator

Baghouses operate by collecting particulate on porous fabric bags, thus resulting in a pressure differential across the system. The gas stream is passed through the fabric which results in pressure; too much pressure indicates a possible plugging of the system and too little indicates possible bag breakage. Therefore, pressure drop is the best indicator of baghouse performance.

C. Rationale for Selection of Indicator Level

Baghouses remove dust from a gas stream by passing the stream through a porous fabric. Particles form a porous cake on the fabric that acts as the filtration device. This porous cake is routinely removed and collected and returned to the process. Baghouses are highly efficient for controlling filterable PM. Baghouses are subject to failure if they are not properly operated and maintained. An indicator pressure drop of 0 to 6 inches of water is recommended to achieve the required control efficiency.

The selected QIP threshold for the daily pressure drop is six excursions during a semi-annual reporting period. If the QIP threshold is exceeded during a semi-annual reporting period, a QIP will be developed and implemented.

#### **IV. General Conditions**

This permit is issued under the authority of the Iowa Code subsection 455B.133(8) and in accordance with 567 Iowa Administrative Code chapter 22.

##### **G1. Duty to Comply**

1. The permittee must comply with all conditions of the Title V permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for a permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. *567 IAC 22.108(9)"a"*
2. Any compliance schedule shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based. *567 IAC 22.105 (2)"h"(3)*
3. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be enforceable by the administrator and are incorporated into this permit. *567 IAC 22.108 (1)"b"*
4. Unless specified as either "state enforceable only" or "local program enforceable only", all terms and conditions in the permit, including provisions to limit a source's potential to emit, are enforceable by the administrator and citizens under the Act. *567 IAC 22.108 (14)*
5. It shall not be a defense for a permittee, in an enforcement action, that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. *567 IAC 22.108 (9)"b"*
6. For applicable requirements with which the permittee is in compliance, the permittee shall continue to comply with such requirements. For applicable requirements that will become effective during the permit term, the permittee shall meet such requirements on a timely basis. *567 IAC 22.108(15)"c"*

##### **G2. Permit Expiration**

1. Except as provided in rule 567—22.104(455B), permit expiration terminates a source's right to operate unless a timely and complete application for renewal has been submitted in accordance with rule 567—22.105(455B). *567 IAC 22.116(2)*
2. To be considered timely, the owner, operator, or designated representative (where applicable) of each source required to obtain a Title V permit shall submit on forms or electronic format specified by the Department to the Air Quality Bureau, Iowa Department of Natural Resources, Air Quality Bureau, Wallace State Office Building, 502 E 9th St., Des Moines, IA 50319-0034, two copies (three if your facility is located in Linn or Polk county) of a complete permit application, at least 6 months but not more than 18 months prior to the date of permit expiration. An additional copy must also be sent to U.S. EPA Region VII, Attention: Chief of Air Permitting & Standards Branch, 11201 Renner Blvd., Lenexa, KS 66219. Additional copies to local programs or EPA are not required for application materials submitted through the electronic format specified by the Department. The application must include all emission points, emission units, air pollution control equipment, and monitoring devices at the facility. All emissions generating activities, including fugitive emissions, must be included. The definition of a complete application is as indicated in 567 IAC 22.105(2). *567 IAC 22.105*

##### **G3. Certification Requirement for Title V Related Documents**

Any application, report, compliance certification or other document submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. All certifications shall state that, based on information and belief formed after reasonable

inquiry, the statements and information in the document are true, accurate, and complete. 567 IAC 22.107 (4)

#### **G4. Annual Compliance Certification**

By March 31 of each year, the permittee shall submit compliance certifications for the previous calendar year. The certifications shall include descriptions of means to monitor the compliance status of all emissions sources including emissions limitations, standards, and work practices in accordance with applicable requirements. The certification for a source shall include the identification of each term or condition of the permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with all applicable department rules. For sources determined not to be in compliance at the time of compliance certification, a compliance schedule shall be submitted which provides for periodic progress reports, dates for achieving activities, milestones, and an explanation of why any dates were missed and preventive or corrective measures. The compliance certification shall be submitted to the administrator, director, and the appropriate DNR Field office. 567 IAC 22.108 (15)"e"

#### **G5. Semi-Annual Monitoring Report**

By March 31 and September 30 of each year, the permittee shall submit a report of any monitoring required under this permit for the 6 month periods of July 1 to December 31 and January 1 to June 30, respectively. All instances of deviations from permit requirements must be clearly identified in these reports, and the report must be signed by a responsible official, consistent with 567 IAC 22.107(4). The semi-annual monitoring report shall be submitted to the director and the appropriate DNR Field office. 567 IAC 22.108 (5)

#### **G6. Annual Fee**

1. The permittee is required under subrule 567 IAC 22.106 to pay an annual fee based on the total tons of actual emissions of each regulated air pollutant. Beginning July 1, 1996, Title V operating permit fees will be paid on July 1 of each year. The fee shall be based on emissions for the previous calendar year.
2. The fee amount shall be calculated based on the first 4,000 tons of each regulated air pollutant emitted each year. The fee to be charged per ton of pollutant will be available from the department by June 1 of each year. The Responsible Official will be advised of any change in the annual fee per ton of pollutant.
3. The emissions inventory shall be submitted annually by March 31 with forms specified by the department documenting actual emissions for the previous calendar year.
4. The fee shall be submitted annually by July 1 with forms specified by the department.
5. If there are any changes to the emission calculation form, the department shall make revised forms available to the public by January 1. If revised forms are not available by January 1, forms from the previous year may be used and the year of emissions documented changed. The department shall calculate the total statewide Title V emissions for the prior calendar year and make this information available to the public no later than April 30 of each year.
6. Phase I acid rain affected units under section 404 of the Act shall not be required to pay a fee for emissions which occur during the years 1993 through 1999 inclusive.
7. The fee for a portable emissions unit or stationary source which operates both in Iowa and out of state shall be calculated only for emissions from the source while operating in Iowa.
8. Failure to pay the appropriate Title V fee represents cause for revocation of the Title V permit as indicated in 567 IAC 22.115(1)"d".

### **G7. Inspection of Premises, Records, Equipment, Methods and Discharges**

Upon presentation of proper credentials and any other documents as may be required by law, the permittee shall allow the director or the director's authorized representative to:

1. Enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
3. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
4. Sample or monitor, at reasonable times, substances or parameters for the purpose of ensuring compliance with the permit or other applicable requirements. *567 IAC 22.108 (15)"b"*

### **G8. Duty to Provide Information**

The permittee shall furnish to the director, within a reasonable time, any information that the director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee also shall furnish to the director copies of records required to be kept by the permit, or for information claimed to be confidential, the permittee shall furnish such records directly to the administrator of EPA along with a claim of confidentiality. *567 IAC 22.108 (9)"e"*

### **G9. General Maintenance and Repair Duties**

The owner or operator of any air emission source or control equipment shall:

1. Maintain and operate the equipment or control equipment at all times in a manner consistent with good practice for minimizing emissions.
2. Remedy any cause of excess emissions in an expeditious manner.
3. Minimize the amount and duration of any excess emission to the maximum extent possible during periods of such emissions. These measures may include but not be limited to the use of clean fuels, production cutbacks, or the use of alternate process units or, in the case of utilities, purchase of electrical power until repairs are completed.
4. Schedule, at a minimum, routine maintenance of equipment or control equipment during periods of process shutdowns to the maximum extent possible. *567 IAC 24.2(1)*

### **G10. Recordkeeping Requirements for Compliance Monitoring**

1. In addition to any source specific recordkeeping requirements contained in this permit, the permittee shall maintain the following compliance monitoring records, where applicable:

- a. The date, place and time of sampling or measurements
- b. The date the analyses were performed.
- c. The company or entity that performed the analyses.
- d. The analytical techniques or methods used.
- e. The results of such analyses; and
- f. The operating conditions as existing at the time of sampling or measurement.
- g. The records of quality assurance for continuous compliance monitoring systems (including but not limited to quality control activities, audits and calibration drifts.)

2. The permittee shall retain records of all required compliance monitoring data and support information for a period of at least 5 years from the date of compliance monitoring sample, measurement report or application. Support information includes all calibration and maintenance

records and all original strip chart recordings for continuous compliance monitoring, and copies of all reports required by the permit.

3. For any source which in its application identified reasonably anticipated alternative operating scenarios, the permittee shall:

- a. Comply with all terms and conditions of this permit specific to each alternative scenario.
- b. Maintain a log at the permitted facility of the scenario under which it is operating.
- c. Consider the permit shield, if provided in this permit, to extend to all terms and conditions under each operating scenario. *567 IAC 22.108(4), 567 IAC 22.108(12)*

**G11. Evidence used in establishing that a violation has or is occurring.**

Notwithstanding any other provisions of these rules, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions herein.

1. Information from the use of the following methods is presumptively credible evidence of whether a violation has occurred at a source:

- a. A monitoring method approved for the source and incorporated in an operating permit pursuant to 567 Chapter 22;
- b. Compliance test methods specified in 567 Chapter 25; or
- c. Testing or monitoring methods approved for the source in a construction permit issued pursuant to 567 Chapter 22.

2. The following testing, monitoring or information gathering methods are presumptively credible testing, monitoring, or information gathering methods:

- a. Any monitoring or testing methods provided in these rules; or
- b. Other testing, monitoring, or information gathering methods that produce information comparable to that produced by any method in subrule 21.5(1) or this subrule. *567 IAC 21.5(1)-567 IAC 21.5(2)*

**G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification**

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Act, the permittee shall notify the department of this requirement. The plan shall be filed with all appropriate authorities by the deadline specified by EPA. A certification that this risk management plan is being properly implemented shall be included in the annual compliance certification of this permit. *567 IAC 22.108(6)*

**G13. Hazardous Release**

The permittee must report any situation involving the actual, imminent, or probable release of a hazardous substance into the atmosphere which, because of the quantity, strength and toxicity of the substance, creates an immediate or potential danger to the public health, safety or to the environment. A verbal report shall be made to the department at (515) 725-8694 and to the local police department or the office of the sheriff of the affected county as soon as possible but not later than six hours after the discovery or onset of the condition. This verbal report must be followed up with a written report as indicated in 567 IAC 131.2(2). *567 IAC Chapter 131-State Only*

**G14. Excess Emissions and Excess Emissions Reporting Requirements**

1. Excess Emissions. Excess emission during a period of startup, shutdown, or cleaning of control equipment is not a violation of the emission standard if the startup, shutdown or cleaning is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions. Cleaning of control equipment which does not require the shutdown of the process

equipment shall be limited to one six-minute period per one-hour period. An incident of excess emission (other than an incident during startup, shutdown or cleaning of control equipment) is a violation. If the owner or operator of a source maintains that the incident of excess emission was due to a malfunction, the owner or operator must show that the conditions which caused the incident of excess emission were not preventable by reasonable maintenance and control measures. Determination of any subsequent enforcement action will be made following review of this report. If excess emissions are occurring, either the control equipment causing the excess emission shall be repaired in an expeditious manner or the process generating the emissions shall be shutdown within a reasonable period of time. An expeditious manner is the time necessary to determine the cause of the excess emissions and to correct it within a reasonable period of time. A reasonable period of time is eight hours plus the period of time required to shut down the process without damaging the process equipment or control equipment. A variance from this subrule may be available as provided for in Iowa Code section 455B.143. In the case of an electric utility, a reasonable period of time is eight hours plus the period of time until comparable generating capacity is available to meet consumer demand with the affected unit out of service, unless, the director shall, upon investigation, reasonably determine that continued operation constitutes an unjustifiable environmental hazard and issue an order that such operation is not in the public interest and require a process shutdown to commence immediately.

## 2. Excess Emissions Reporting

a. Initial Reporting of Excess Emissions. An incident of excess emission (other than an incident of excess emission during a period of startup, shutdown, or cleaning) shall be reported to the appropriate field office of the department within eight hours of, or at the start of the first working day following the onset of the incident. The reporting exemption for an incident of excess emission during startup, shutdown or cleaning does not relieve the owner or operator of a source with continuous monitoring equipment of the obligation of submitting reports required in 567-subrule 25.1(6). An initial report of excess emission is not required for a source with operational continuous monitoring equipment (as specified in 567-subrule 25.1(1) ) if the incident of excess emission continues for less than 30 minutes and does not exceed the applicable emission standard by more than 10 percent or the applicable visible emission standard by more than 10 percent opacity. The initial report may be made by electronic mail (E-mail), in person, or by telephone and shall include as a minimum the following:

- i. The identity of the equipment or source operation from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and expected duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps being taken to remedy the excess emission.
- vi. The steps being taken to limit the excess emission in the interim period.

b. Written Reporting of Excess Emissions. A written report of an incident of excess emission shall be submitted as a follow-up to all required initial reports to the department within seven days of the onset of the upset condition, and shall include as a minimum the following:

- i. The identity of the equipment or source operation point from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.

- iii. The time and duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps that were taken to remedy and to prevent the recurrence of the incident of excess emission.
- vi. The steps that were taken to limit the excess emission.
- vii. If the owner claims that the excess emission was due to malfunction, documentation to support this claim. *567 IAC 24.1(1)-567 IAC 24.1(4)*

3. Emergency Defense for Excess Emissions. For the purposes of this permit, an “emergency” means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include non-compliance, to the extent caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation or operator error. An emergency constitutes an affirmative defense to an action brought for non-compliance with technology based limitations if it can be demonstrated through properly signed contemporaneous operating logs or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The facility at the time was being properly operated;
- c. During the period of the emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements of the permit; and
- d. The permittee submitted notice of the emergency to the director by certified mail within two working days of the time when the emissions limitations were exceeded due to the emergency. This notice fulfills the requirement of paragraph 22.108(5)"b." – See G15. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof. This provision is in addition to any emergency or upset provision contained in any applicable requirement. *567 IAC 22.108(16)*

#### **G15. Permit Deviation Reporting Requirements**

A deviation is any failure to meet a term, condition or applicable requirement in the permit. Reporting requirements for deviations that result in a hazardous release or excess emissions have been indicated above (see G13 and G14). Unless more frequent deviation reporting is specified in the permit, any other deviation shall be documented in the semi-annual monitoring report and the annual compliance certification (see G4 and G5). *567 IAC 22.108(5)"b"*

#### **G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations**

During the term of this permit, the permittee must notify the department of any source that becomes subject to a standard or other requirement under 567-subrule 23.1(2) (standards of performance of new stationary sources) or section 111 of the Act; or 567-subrule 23.1(3) (emissions standards for hazardous air pollutants), 567-subrule 23.1(4) (emission standards for hazardous air pollutants for source categories) or section 112 of the Act. This notification shall be submitted in writing to the department pursuant to the notification requirements in 40 CFR

Section 60.7, 40 CFR Section 61.07, and/or 40 CFR Section 63.9. *567 IAC 23.1(2), 567 IAC 23.1(3), 567 IAC 23.1(4)*

### **G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification**

1. Off Permit Changes to a Source. Pursuant to section 502(b)(10) of the CAAA, the permittee may make changes to this installation/facility without revising this permit if:

- a. The changes are not major modifications under any provision of any program required by section 110 of the Act, modifications under section 111 of the act, modifications under section 112 of the act, or major modifications as defined in 567 IAC Chapter 22.
- b. The changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions);
- c. The changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or as total emissions);
- d. The changes are not subject to any requirement under Title IV of the Act (revisions affecting Title IV permitting are addressed in rules 567—22.140(455B) through 567 - 22.144(455B));
- e. The changes comply with all applicable requirements.
- f. For each such change, the permitted source provides to the department and the administrator by certified mail, at least 30 days in advance of the proposed change, a written notification, including the following, which must be attached to the permit by the source, the department and the administrator:
  - i. A brief description of the change within the permitted facility,
  - ii. The date on which the change will occur,
  - iii. Any change in emission as a result of that change,
  - iv. The pollutants emitted subject to the emissions trade
  - v. If the emissions trading provisions of the state implementation plan are invoked, then Title V permit requirements with which the source shall comply; a description of how the emissions increases and decreases will comply with the terms and conditions of the Title V permit.
  - vi. A description of the trading of emissions increases and decreases for the purpose of complying with a federally enforceable emissions cap as specified in and in compliance with the Title V permit; and
  - vii. Any permit term or condition no longer applicable as a result of the change.

*567 IAC 22.110(1)*

2. Such changes do not include changes that would violate applicable requirements or contravene federally enforceable permit terms and conditions that are monitoring (including test methods), record keeping, reporting, or compliance certification requirements. *567 IAC 22.110(2)*

3. Notwithstanding any other part of this rule, the director may, upon review of a notice, require a stationary source to apply for a Title V permit if the change does not meet the requirements of subrule 22.110(1). *567 IAC 22.110(3)*

4. The permit shield provided in subrule 22.108(18) shall not apply to any change made pursuant to this rule. Compliance with the permit requirements that the source will meet using the emissions trade shall be determined according to requirements of the state implementation plan authorizing the emissions trade. *567 IAC 22.110(4)*

5. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes, for changes that are provided for in this permit. *567 IAC 22.108(11)*

### **G18. Duty to Modify a Title V Permit**

#### 1. Administrative Amendment.

- a. An administrative permit amendment is a permit revision that does any of the following:
  - i. Correct typographical errors
  - ii. Identify a change in the name, address, or telephone number of any person identified in the permit, or provides a similar minor administrative change at the source;
  - iii. Require more frequent monitoring or reporting by the permittee; or
  - iv. Allow for a change in ownership or operational control of a source where the director determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new permittee has been submitted to the director.
- b. The permittee may implement the changes addressed in the request for an administrative amendment immediately upon submittal of the request. The request shall be submitted to the director.
- c. Administrative amendments to portions of permits containing provisions pursuant to Title IV of the Act shall be governed by regulations promulgated by the administrator under Title IV of the Act.

#### 2. Minor Title V Permit Modification.

- a. Minor Title V permit modification procedures may be used only for those permit modifications that satisfy all of the following:
  - i. Do not violate any applicable requirement;
  - ii. Do not involve significant changes to existing monitoring, reporting or recordkeeping requirements in the Title V permit;
  - iii. Do not require or change a case by case determination of an emission limitation or other standard, or an increment analysis;
  - iv. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed in order to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include any federally enforceable emissions caps which the source would assume to avoid classification as a modification under any provision under Title I of the Act; and an alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Act;
  - v. Are not modifications under any provision of Title I of the Act; and
  - vi. Are not required to be processed as significant modification under rule 567 - 22.113(455B).
- b. An application for minor permit revision shall be on the minor Title V modification application form and shall include at least the following:
  - i. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;

- ii. The permittee's suggested draft permit;
  - iii. Certification by a responsible official, pursuant to 567 IAC 22.107(4), that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used; and
  - iv. Completed forms to enable the department to notify the administrator and the affected states as required by 567 IAC 22.107(7).
- c. The permittee may make the change proposed in its minor permit modification application immediately after it files the application. After the permittee makes this change and until the director takes any of the actions specified in 567 IAC 22.112(4) "a" to "c", the permittee must comply with both the applicable requirements governing the change and the proposed permit terms and conditions. During this time, the permittee need not comply with the existing permit terms and conditions it seeks to modify. However, if the permittee fails to comply with its proposed permit terms and conditions during this time period, the existing permit terms and conditions it seeks to modify may be enforced against the facility.

### 3. Significant Title V Permit Modification.

Significant Title V modification procedures shall be used for applications requesting Title V permit modifications that do not qualify as minor Title V modifications or as administrative amendments. These include but are not limited to all significant changes in monitoring permit terms, every relaxation of reporting or recordkeeping permit terms, and any change in the method of measuring compliance with existing requirements. Significant Title V modifications shall meet all requirements of 567 IAC Chapter 22, including those for applications, public participation, review by affected states, and review by the administrator, as those requirements that apply to Title V issuance and renewal.

The permittee shall submit an application for a significant permit modification not later than three months after commencing operation of the changed source unless the existing Title V permit would prohibit such construction or change in operation, in which event the operation of the changed source may not commence until the department revises the permit. *567 IAC 22.111-567 IAC 22.113*

#### **G19. Duty to Obtain Construction Permits**

Unless exempted in 567 IAC 22.1(2) or to meet the parameters established in 567 IAC 22.1(1)"c", the permittee shall not construct, install, reconstruct or alter any equipment, control equipment or anaerobic lagoon without first obtaining a construction permit, or conditional permit, or permit pursuant to rule 567 IAC 22.8, or permits required pursuant to rules 567 IAC 22.4, 567 IAC 22.5, 567 IAC 31.3, and 567 IAC 33.3 as required in 567 IAC 22.1(1). A permit shall be obtained prior to the initiation of construction, installation or alteration of any portion of the stationary source or anaerobic lagoon. *567 IAC 22.1(1)*

#### **G20. Asbestos**

The permittee shall comply with 567 IAC 23.1(3)"a", and 567 IAC 23.2(3)"g" when activities involve asbestos mills, surfacing of roadways, manufacturing operations, fabricating, insulating, waste disposal, spraying applications, demolition and renovation operations (*567 IAC 23.1(3)"a"*); training fires and controlled burning of a demolished building (*567 IAC 23.2*).

#### **G21. Open Burning**

The permittee is prohibited from conducting open burning, except as provided in 567 IAC 23.2. *567 IAC 23.2 except 23.2(3)"j"; 567 IAC 23.2(3)"j" - State Only*

## **G22. Acid Rain (Title IV) Emissions Allowances**

The permittee shall not exceed any allowances that it holds under Title IV of the Act or the regulations promulgated there under. Annual emissions of sulfur dioxide in excess of the number of allowances to emit sulfur dioxide held by the owners and operators of the unit or the designated representative of the owners and operators is prohibited. Exceedences of applicable emission rates are prohibited. "Held" in this context refers to both those allowances assigned to the owners and operators by USEPA, and those allowances supplementally acquired by the owners and operators. The use of any allowance prior to the year for which it was allocated is prohibited. Contravention of any other provision of the permit is prohibited. *567 IAC 22.108(7)*

## **G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements**

1. The permittee shall comply with the standards for labeling of products using ozone-depleting substances pursuant to 40 CFR Part 82, Subpart E:
  - a. All containers in which a class I or class II substance is stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced into interstate commerce pursuant to § 82.106.
  - b. The placement of the required warning statement must comply with the requirements pursuant to § 82.108.
  - c. The form of the label bearing the required warning statement must comply with the requirements pursuant to § 82.110.
  - d. No person may modify, remove, or interfere with the required warning statement except as described in § 82.112.
2. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for MVACs in Subpart B:
  - a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to § 82.156.
  - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to § 82.158.
  - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to § 82.161.
  - d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with reporting and recordkeeping requirements pursuant to § 82.166. ("MVAC-like appliance" as defined at § 82.152)
  - e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to § 82.156.
  - f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to § 82.166.
3. If the permittee manufactures, transforms, imports, or exports a class I or class II substance, the permittee is subject to all the requirements as specified in 40 CFR part 82, Subpart A, Production and Consumption Controls.
4. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle

has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or system used on passenger buses using HCFC-22 refrigerant,

5. The permittee shall be allowed to switch from any ozone-depleting or greenhouse gas generating substances to any alternative that is listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR part 82, Subpart G, Significant New Alternatives Policy Program. *40 CFR part 82*

#### **G24. Permit Reopenings**

1. This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. *567 IAC 22.108(9)"c"*

2. Additional applicable requirements under the Act become applicable to a major part 70 source with a remaining permit term of 3 or more years. Revisions shall be made as expeditiously as practicable, but not later than 18 months after the promulgation of such standards and regulations.

a. Reopening and revision on this ground is not required if the permit has a remaining term of less than three years;

b. Reopening and revision on this ground is not required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions have been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii) as amended to May 15, 2001.

c. Reopening and revision on this ground is not required if the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. *567 IAC 22.108(17)"a"*, *567 IAC 22.108(17)"b"*

3. A permit shall be reopened and revised under any of the following circumstances:

a. The department receives notice that the administrator has granted a petition for disapproval of a permit pursuant to 40 CFR 70.8(d) as amended to July 21, 1992, provided that the reopening may be stayed pending judicial review of that determination;

b. The department or the administrator determines that the Title V permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Title V permit;

c. Additional applicable requirements under the Act become applicable to a Title V source, provided that the reopening on this ground is not required if the permit has a remaining term of less than three years, the effective date of the requirement is later than the date on which the permit is due to expire, or the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. Such a reopening shall be complete not later than 18 months after promulgation of the applicable requirement.

d. Additional requirements, including excess emissions requirements, become applicable to a Title IV affected source under the acid rain program. Upon approval by the administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

e. The department or the administrator determines that the permit must be revised or

revoked to ensure compliance by the source with the applicable requirements. *567 IAC 22.114(1)*

4. Proceedings to reopen and reissue a Title V permit shall follow the procedures applicable to initial permit issuance and shall effect only those parts of the permit for which cause to reopen exists. *567 IAC 22.114(2)*

5. A notice of intent shall be provided to the Title V source at least 30 days in advance of the date the permit is to be reopened, except that the director may provide a shorter time period in the case of an emergency. *567 IAC 22.114(3)*

#### **G25. Permit Shield**

1. The director may expressly include in a Title V permit a provision stating that compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:

a. Such applicable requirements are included and are specifically identified in the permit; or

b. The director, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the source, and the permit includes the determination or a concise summary thereof.

2. A Title V permit that does not expressly state that a permit shield exists shall be presumed not to provide such a shield.

3. A permit shield shall not alter or affect the following:

a. The provisions of Section 303 of the Act (emergency orders), including the authority of the administrator under that section;

b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;

c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the Act;

d. The ability of the department or the administrator to obtain information from the facility pursuant to Section 114 of the Act. *567 IAC 22.108 (18)*

#### **G26. Severability**

The provisions of this permit are severable and if any provision or application of any provision is found to be invalid by this department or a court of law, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected by such finding. *567 IAC 22.108 (8)*

#### **G27. Property Rights**

The permit does not convey any property rights of any sort, or any exclusive privilege. *567 IAC 22.108 (9)"d"*

#### **G28. Transferability**

This permit is not transferable from one source to another. If title to the facility or any part of it is transferred, an administrative amendment to the permit must be sought consistent with the requirements of *567 IAC 22.111(1)*. *567 IAC 22.111 (1)"d"*

#### **G29. Disclaimer**

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. *567 IAC 22.3(3)"c"*

#### **G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification**

The permittee shall notify the department's stack test contact in writing not less than 30 days before a required test or performance evaluation of a continuous emission monitor is performed

to determine compliance with applicable requirements of 567 – Chapter 23 or a permit condition. Such notice shall include the time, the place, the name of the person who will conduct the test and other information as required by the department. If the owner or operator does not provide timely notice to the department, the department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with applicable rules or permit conditions. Upon written request, the department may allow a notification period of less than 30 days. At the department's request, a pretest meeting shall be held not later than 15 days prior to conducting the compliance demonstration. A testing protocol shall be submitted to the department no later than 15 days before the owner or operator conducts the compliance demonstration. A representative of the department shall be permitted to witness the tests. Results of the tests shall be submitted in writing to the department's stack test contact in the form of a comprehensive report within six weeks of the completion of the testing. Compliance tests conducted pursuant to this permit shall be conducted with the source operating in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which the source shall be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the equipment manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the department that the source has been physically altered so that capacity cannot be exceeded, or the department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the department to determine whether such source is in compliance.

Stack test notifications, reports and correspondence shall be sent to:

Stack Test Review Coordinator  
Iowa DNR, Air Quality Bureau  
Wallace State Office Building  
502 E 9<sup>th</sup> St.  
Des Moines, IA 50319-0034  
(515) 725-9526

Within Polk and Linn Counties, stack test notifications, reports and correspondence shall also be directed to the supervisor of the respective county air pollution program.

*567 IAC 25.1(7)"a", 567 IAC 25.1(9)*

### **G31. Prevention of Air Pollution Emergency Episodes**

The permittee shall comply with the provisions of 567 IAC Chapter 26 in the prevention of excessive build-up of air contaminants during air pollution episodes, thereby preventing the occurrence of an emergency due to the effects of these contaminants on the health of persons.

*567 IAC 26.1(1)*

**G32. Contacts List**

The current address and phone number for reports and notifications to the EPA administrator is:

Iowa Compliance Officer  
Air Branch  
Enforcement and Compliance Assurance Division  
U.S. EPA Region 7  
11201 Renner Blvd.  
Lenexa, KS 66219  
(913) 551-7020

The current address and phone number for reports and notifications to the department or the Director is:

Chief, Air Quality Bureau  
Iowa Department of Natural Resources  
Wallace State Office Building  
  
502 E 9<sup>th</sup> St.  
Des Moines, IA 50319-0034  
(515) 725-8200

Reports or notifications to the DNR Field Offices or local programs shall be directed to the supervisor at the appropriate field office or local program. Current addresses and phone numbers are:

**Field Office 1**  
909 West Main – Suite 4  
Manchester, IA 52057  
(563) 927-2640

**Field Office 2**  
2300-15th St., SW  
Mason City, IA 50401  
(641) 424-4073

**Field Office 3**  
1900 N. Grand Ave.  
Spencer, IA 51301  
(712) 262-4177

**Field Office 4**  
1401 Sunnyside Lane  
Atlantic, IA 50022  
(712) 243-1934

**Field Office 5**  
Wallace State Office Building  
502 E 9<sup>th</sup> St.  
Des Moines, IA 50319-0034  
(515) 725-0268

**Field Office 6**  
1023 West Madison Street  
Washington, IA 52353-1623  
(319) 653-2135

**Polk County Public Works Dept.**  
Air Quality Division  
5885 NE 14th St.  
Des Moines, IA 50313  
(515) 286-3351

**Linn County Public Health**  
Air Quality Branch  
501 13th St., NW  
Cedar Rapids, IA 52405  
(319) 892-6000

## V. Appendix A

A. 40 CFR 60 Subpart A - *General Provisions*

[https://www.ecfr.gov/cgi-bin/text-idx?tpl=/ecfrbrowse/Title40/40cfr60\\_main\\_02.tpl](https://www.ecfr.gov/cgi-bin/text-idx?tpl=/ecfrbrowse/Title40/40cfr60_main_02.tpl)

B. 40 CFR 60 Subpart DD - Standards of Performance for Grain Elevators

<https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.7.60.dd>

C. 40 CFR 60 Subpart Db - Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units

[https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.7.60.d\\_0b](https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.7.60.d_0b)

D. 40 CFR 60 Subpart Kb - Standards of Performance for Volatile Organic Liquid Storage Vessels (including Petroleum Liquid Storage Vessels)

[https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.7.60.k\\_0b](https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.7.60.k_0b)

E. 40 CFR 60 Subpart VVa - Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction or Modification Commenced after November 7, 2006

[https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.7.60.vv\\_0a](https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.7.60.vv_0a)

F. 40 CFR 60 Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

<https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.7.60.iiii>

G. 40 CFR 63 Subpart A - National Emission Standards for Hazardous Air Pollutants for Source Category: General Provisions

[https://www.ecfr.gov/cgi-bin/text-idx?tpl=/ecfrbrowse/Title40/40cfr63\\_main\\_02.tpl](https://www.ecfr.gov/cgi-bin/text-idx?tpl=/ecfrbrowse/Title40/40cfr63_main_02.tpl)

H. 40 CFR 63 Subpart FFFF - National Emission Standards for Hazardous Air Pollutants: Miscellaneous Organic Chemical Manufacturing

<https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.13.63.ffff>

I. 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)

<https://www.ecfr.gov/cgi-bin/text-idx?c=ecfr;rgn=div6;view=text;node=40%3A14.0.1.1.1.1;idno=40;sid=e94dcfde4a04b27290c445a56e635e58;cc=ecfr>