

**Iowa Department of Natural Resources
2022 Summary Information Underground Storage Tanks (USTs)**

General Information

Public Record Posted Date: 10/11/2022

Total Number of Active UST Facilities: 2472
 Total Number of Active USTs: 6543
 Total Number Of Active UST Compartments: 7884

Summary Information for On-Site Inspections

Number of UST Facilities Inspected: 1275
 Inspection Period Dates: 10/1/2021 To: 9/30/2022
 Percent Compliance (Technical Compliance Rate Measure): 18%

Note: Tank, facility, and on-site inspection information is based on underground storage tanks in operation and inspected during federal fiscal year 2023. On-site inspections measure compliance with federal and state regulations for operating underground storage tanks.

Summary Information for Releases

Number of Confirmed UST Releases: 25
 Release Reporting Period Dates: 10/1/2021 To: 9/30/2022

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank																
Piping	2	8%							1	4%	1	4%				
Dispenser	7	28%					7	28%								
STP	1	4%					1	4%								
Delivery Problem																
Other	15	60%													15	60%
Totals	25	100%					8	32%	1	4%	1	4%			15	60%

= number, % = percent of total number of releases

Note: Release, source, and cause information is based on releases from underground storage tanks regulated by the Iowa Department of Natural Resources.

Questions about the general information, on-site inspections, and confirmed releases may be addressed to the Iowa DNR UST Section at 515-725-8450. Site specific information also can be reviewed on the Storage Tanks Database Web Application at <https://programs.iowadnr.gov/tanks/pages/advanced.aspx>.