

**Iowa Department of Natural Resources
2024 Summary Information Underground Storage Tanks (USTs)**

General Information

Public Record Posted Date: 10/18/2024

Total Number of Active UST Facilities: 2418
 Total Number of Active USTs: 6487
 Total Number Of Active UST Compartments: 7868

Summary Information for On-Site Inspections

Number of UST Facilities Inspected: 1525
 Inspection Period Dates: 10/1/2023 To: 9/30/2024
 Percent Compliance (Technical Compliance Rate Measure): 34%

Note: Tank, facility, and on-site inspection information is based on underground storage tanks in operation and inspected during federal fiscal year 2024. On-site inspections measure compliance with federal and state regulations for operating underground storage tanks.

Summary Information for Releases

Number of Confirmed UST Releases: 16
 Release Reporting Period Dates: 10/1/2023 To: 9/30/2024

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	
Tank																
Piping																
Dispenser	4	25%					4	25%								
STP	1	6%					1	6%								
Delivery Problem																
Other	11	69%					1	6%					1	6%	9	56%
Totals	16	100%					6	38%					1	6%	9	56%

= number, % = percent of total number of releases

Note: Release, source, and cause information is based on releases from underground storage tanks regulated by the Iowa Department of Natural Resources.

Questions about the general information, on-site inspections, and confirmed releases may be addressed to the Iowa DNR UST Section at 515-725-8450. Site specific information also can be reviewed on the Storage Tanks Database Web Application at <https://programs.iowadnr.gov/tanks/pages/advanced.aspx>.